


NOTES:

1. ALL BOLTED CONNECTIONS TO USE GALVANISED MILD STEEL BOLTS, SPRING WASHERS, LARGE FLAT WASHERS AND GALVANISED NUTS.
2. GREASE TO USED ON ALL BOLTED CONNECTIONS.
3. FOR UNDERGROUND EARTHING REFER EITHER S01-02-03-11, S01-02-03-12 OR S01-02-03-13.
4. REFER TO S01-04-04-01 PN PROCEDURE 'POLE INSTALLATION PROCEDURE (CIVIL WORKS)' FOR THE REQUIREMENT & INSTALLATION OF POLE CONCRETE FOUNDATIONS.



15	5	M16x180 GALV. STEEL BOLT C/W NUT	114561	S01-01-04-43
	10	M16 65x65x5 SQUARE GALV. STEEL WASHER	298695	
	5	M16 GALV. STEEL SPRING WASHER	114322	
14	1	M16x60 GALV. STEEL BOLT C/W NUT	500875	S01-01-04-43
	2	M16 65x65x5 SQUARE GALV. STEEL WASHER	298695	
	1	M16 GALV. STEEL SPRING WASHER	114322	
13	3	M24x220 GALV. STEEL BOLT C/W NUT	400803	S01-01-04-43
	6	M24 75x75x5 SQUARE GALV. STEEL WASHER	298828	
	3	M24 GALV. STEEL SPRING WASHER	114330	
12	3	M24x65 GALV. STEEL BOLT C/W NUT	400800	S01-01-04-43
	6	M24 75x75x5 SQUARE GALV. STEEL WASHER	298828	
	3	M24 GALV. STEEL SPRING WASHER	114330	
11	2	M24x180 GALV. STEEL BOLT C/W NUT	400802	S01-01-04-43
	4	M24 75x75x5 SQUARE GALV. STEEL WASHER	298828	
	2	M24 GALV. STEEL SPRING WASHER	114330	
10	4	CROSSARM BRACE 50x5 DURAGAL	298687	S01-01-04-38
9	2	CROSSARM BRACE 75x75x5 DURAGAL CA	400815	S01-01-04-38
8	1	GBS HANGING ARM, SIDE MOUNT 125x125x5 DURAGAL	400813	S01-01-06-17
7	AR	TREFOIL CABLE CLAMPS	-	-
5	1	LV CROSSARM, 150x75x5 DURAGAL PFC	298604	S01-01-02-12
4	1	HV CROSSARM, 125x65x4 DURAGAL CC	298539	S01-01-02-10
2	1	HV CROSSARM, FIBREGLASS 100x100x5	298802	S01-01-02-10
1	1	LINE POLE, UNIVERSAL POLE	-	-
ITEM	QTY	DESCRIPTION	ITEM NUMBER	DRG. REF.

MATERIAL SCHEDULE

5	REFORMATTED NOTES AND TABLE. UPDATED ITEMS 2, 4, 5, 7, 8, 9, 10, 11, 12, 13, 14 & 15	A.N.	JUL '21	A.N.	B.C.
4	TITLEBLOCK & DRAWING NUMBERS FORMATTED	K.T.	JAN '19	C.C.	C.C.
3	ITEM NUMBER AMENDED	C.C.	MAY '18	I.B.	B.C.
2	MATERIAL SCHEDULE UPDATED, POLE FOUNDATION REMOVED, NOTE 4 ADDED	K.T.	MAY '16	I.B.	B.C.
1	NOTE 3 AMENDED, ITEM 3 AND 6 REMOVED, STOCK CODES UPDATED	A.T.	AUG '11	B.N.	B.C.
0	ISSUED FOR CONSTRUCTION	K.I.	JUL '05	C.C.	C.C.
NO	DESCRIPTION	DRN	DATE	CKD	APPD
AMENDMENTS					

**PowerWater**  
NORTHERN TERRITORY

DES	...	POWER STANDARD DRAWING		
DRN	K. IBBOTT	<b>POLE STRUCTURES HV BOLTED CONNECTIONS CABLE TERMINATION WITH GBS</b>		
CKD	C. CAMILLERI			
APPD	...			
SCALE	NTS			
ISSUED	JUN '05	A3	DRAWING NUMBER	S01-02-05-31
ALL DIM.	IN mm			
DRAFTING STANDARD TO A.S.1100		CAD PRODUCT - DO NOT AMEND MANUALLY		