


SIDE VIEW



ITEM 3 POLE DATA NAMEPLATE (EXAMPLE)

SCALE - NTS

NOTES

- 1. CENTRE OF GRAVITY / LIFTING POINT SHALL BE MARKED ON EACH SECTION
- TWO PIECE SPLICED POLE IS NOT THE PREFERRED OPTION FOR GREENFIELD SITES.
- 3. REFER TO S01-02-01-69 FOR INSTALLATION DETAILS
- 4. APPLICATION OF THIS POLE IS RESTRICTED FOR INTERNAL POWER NETWORKS USE ONLY FOR OTHER APPLICATIONS AND APPROVALS, CONTACT POWER NETWORKS STANDARDS
- 5. POLES TO COMPLY WITH PWC DOCUMENT STSP 01-002
- 6. ALL WELDS TO BE 6mm FILLET CONTINUOUS WELD UNO EXCEPT ANTICLIMB PLATE WHICH IS TO HAVE 6mm FILLET 150mm LONG AT BOTH ENDS AND CENTRE
- 7. FOR SPLICE DETAILS REFER TO DRG S01-01-01-40

TWO PIECE SPLICED POLE 15.0D - ITEM NUMBER: 505060

TOTAL MASS 15.0D - TOP - 1017Kg
TOTAL MASS 15.0D - BOTTOM - 502Kg

ITEM	QTY. 15.0D	MATERIAL DESCRIPTION				
1	2	670 X 250 X 25 FMS FLANGE PL T 26 DIA HOLES , REFER DRG SOL-01-01-40				
2	4	218 X 200 X 8 FMS STIFFENER PL T . REFER DRG SOL-01-01-40				
3	2	POLE DATA NAME PLATE				
4	-	REFER DRG SOL-01-01-23 FOR ALL OTHER POLE MATERIALS				

	ITEM 1 (FLANGE) DIMENSION AMENDED. ISSUED FOR CONSTRUCTION	P.BH. P.G.	APR'24 DEC'23	J.R. B.C.	B.V. B.V.
NO	DESCRIPTION	DRN	DATE	CKD	APPD
	AMENDMENTS				



	DES	B.VANDERSTELT		POWER STANDARD DRAWING						
	DRN	P.GUNURAJAN	T_/0	DIFCE SD	LICED POLE					
	CKD	B.CHEUNG		LINE 15.0D						
	APPD	B.VANDERSTELT		BOLTED CONNECTIONS TYPE						
	SCALE	1:50	DOLILD CONNECTIONS TIPE							
	ISSUED	DEC'23	۸٦	DRAWING	501 01 01 / 2					
	ALL DIM. IN mm		A3	NUMBER	S01-01-01-42		<u> </u>			
DRAFTING STANDARD TO A.S.1100			A.S.1100	CAD PR	ODUCT - DO NOT AMEND MANUALLY		AMDT			