

NTS


1. CENTRE OF GRAVITY / LIFTING POINT SHALL BE MARKED ON EACH SECTION
2. TWO PIECE SPLICED POLE IS NOT THE PREFERRED OPTION FOR GREENFIELD SITES
4. REFER TO S01-02-01-69 FOR INSTALLATION DETAILS
5. APPLICATION OF THIS POLE IS RESTRICTED FOR INTERNAL POWER NETWORKS USE ONLY. FOR OTHER APPLICATIONS AND APPROVALS, CONTACT POWER NETWORKS STANDARDS
6. POLES TO COMPLY WITH PWC DOCUMENT STSP 01-002
7. ALL WELDS TO BE 6mm FILLET CONTINUOUS WELD UNO EXCEPT ANTICLIMB PLATE WHICH IS TO HAVE 6mm FILLET 150mm LONG AT BOTH ENDS AND CENTRE.
8. FOR SPLICE DETAILS REFER TO DRG S01-01-01-40

TOTAL MASS 10.5C - TOP - 466Kg
TOTAL MASS 10.5C - BOTTOM - 242Kg

ITEM	QTY. 10.5B	QTY. 10.5C	MATERIAL DESCRIPTION
1	2	-	602 x 150 x 25 FMS. FLANGE PLT. 26 DIA HOLES, REFER DRG S01-01-01-40
2	-	2	602 x 200 x 25 FMS. FLANGE PLT. 26 DIA HOLES, REFER DRG S01-01-01-40
3	4	-	128 x 200 x 8 FMS. STIFFENER PLT. NOTCHED 25x25mm, REFER DRG S01-01-01-40
4	-	4	174 x 200 x 8 FMS. STIFFENER PLT. NOTCHED 25x25mm, REFER DRG S01-01-01-40
5	2	2	POLE DATA NAMEPLATE
6	-	-	REFER DRG S01-01-01-08 FOR ALL OTHER POLE MATERIALS

2	AMENDED WEB CORNERS FOR HDG, AMENDED IMAGERY NOTE 3 REMOVED, ADDED	P.G.	MAR'23	B.V.	B.C.
1	NOTES 6,7 & 8. ADDED ITEM 6. POLE DATA NAMEPLATE AMENDED.	K.T.	DEC'16	C.C.	C.C.
0	TITLEBLOCK & DRAWING NUMBERS FORMATTED	J.N.	FEB'16	A.T	I.B.
	ISSUED FOR CONSTRUCTION				
NO	DESCRIPTION	DRN	DATE	CKD	APPD
AMENDMENTS					



DES	M. BOCK	POWER STANDARD DRAWING			
DRN	A. TAYLOR	TWO PIECE SPLICED POLE LINE 10.5B AND 10.5C BOLTED CONNECTIONS TYPE			
CKD	I. BASHIR				
APPD	-				
SCALE	AS NOTED				
ISSUED	FEB' 16	A3	DRAWING NUMBER	S01-01-01-31	
ALL DIM. IN mm					
DRAFTING STANDARD TO A.S.1100		CAD PRODUCT - DO NOT AMEND MANUALLY			AMD