


NOTES:

- BUSBAR TO CONFORM TO AS1567 AND AS3000 APPENDIX C, AND BE SUPPLIED IN 4m LENGTHS.
- BUSBAR MATERIAL TO BE COPPER HIGH CONDUCTIVITY ALLOY C11000.



COPPER BUSB-R			
ITEM	ITEM NUMBER	DIMENSIONS	
		-	B
1	3020	25	4
2	3038	25	6.30
3	3079	50	6.30
4	3053	76.2	6.35
5	3061	100	6.30
6	3095	50	10.00

TINNED COPPER BUSB-R			
ITEM	ITEM NUMBER	DIMENSIONS	
		-	B
1	504108	25	4
2	504109	25	6.30
3	504110	50	6.30
4	504111	80.0	6.30
5	504112	100	6.30
6	504113	50	10.00

15	TITLEBLOCK & DRAWING NUMBER FORMATTED, UPDATE ALLOY STANDARD	K.T.	DEC'18	C.C.	C.C.
14	UPDATE DIMENSIONS ITEM 504111	C.C.	OCT'18	B.V.	B.C.
13	SUPERSEDED COPPER BUSBAR, ADDED TINNED COPPER BUSBAR	PH	DEC'17	B.V.	B.C.
12	LOGO CHANGED	C.C.	JAN'11	A.T.	S.C.
NO	DESCRIPTION	DRN	DATE	CKD	APPD
AMENDMENTS					

PowerWater
NORTHERN TERRITORY

DES	R.HAIGH	POWER STANDARD DRAWING		
DRN	R.INNES	EARTHING BUSBAR COPPER RECTANGULAR		
CKD	AGB			
APPD	...			
SCALE	N.T.S.			
ISSUED	1996	A3	DRAWING NUMBER	S01-01-05-06
ALL DIM.	IN mm			
DRAFTING STANDARD TO A.S.1100			CAD PRODUCT - DO NOT AMEND MANUALLY	