



NOTES:

1. EASEMENT GROUND SHALL BE LEVEL REGARDLESS OF EXISTING GROUND PROFILE, REFER DETAIL A.
2. WHERE REQUIRED, A RETAINING WALL SHALL BE BUILT ALONG THE OUTER EDGE OF THE EASEMENT WITH THE ABILITY TO DIVERT FLOWING WATER AROUND THE EASEMENT.
3. ALL RETAINING WALLS SHALL BE CERTIFIED BY A CIVIL ENGINEER.
4. OPTIONAL 50mm WIDE CONCRETE STRIP FOOTING CAN BE BUILT ALONG THE EASEMENT EDGE.
5. THIS DRAWING SHALL BE APPLICABLE TO ALL GROUND MOUNTED INSTALLATIONS E.G. SUBSTATIONS, RMUS, ETC.
6. FOUNDATION AND APRON SHALL BE FINISHED TO PREVENT WATER POOLING. ADDITIONAL GUTTERING OR DRAINAGE MAY BE REQUIRED IN PROBLEM AREAS.

						DES	A.T.	POWER STANDARD DRAWING			
						DRN	A.T.	GROUND LEVEL DETAILS PACKAGE SUBSTATIONS AND RING MAIN UNITS			
						CKD	B.C.				
						APPD	B.C.				
						SCALE	N.T.S.	A3	DRAWING NUMBER	S02-02-06-33	5 AMDT
						ISSUED	MAY'13				
						ALL DIM.	IN mm	CAD PRODUCT - DO NOT AMEND MANUALLY			
						DRAFTING STANDARD TO A.S.1100					

NO	DESCRIPTION	DRN	DATE	CKD	APPD
5	SPELLING MISTAKE CORRECTED	CWM	JUNE '20	B.V.	B.V.
4	TITLEBLOCK & DRAWING NUMBER FORMATTED	K.T.	FEB'19	C.C.	C.C.
3	CONCRETE APRON DIMENSION CHANGES	P.H.	DEC'17	B.C.	B.V.
2	ADJUSTED FOUNDATION	CWM	AUG'17	B.V.	B.C.
1	CONCRETE APRON RAISED	A.T.	MAR'15	I.B.	B.C.
0	ISSUED FOR CONSTRUCTION	A.T.	JUL'13	B.C.	B.C.

