



NOTES:-
 CONDUIT ENTRY DETAILS TO BE
 USED WHEN INSTALLING MK2
 SUBSTATION CONCRETE SLAB
 REF: S02-2-6-31_2

CONDUIT ENTRY DETAILS

SCALE 1:25

REFERENCE DRAWINGS AND DOCUMENTS	
DOCUMENT No.	DOCUMENT TITLE
S02-1-7-18	SUBSTATION MK3 PACKAGE SUBSTATION GENERAL ARRANGEMENT
S02-2-5-10	EARTHING - PACKAGE SUBSTATION MK2 - CONSTRUCTION DETAILS
S02-2-6-33	GROUND LEVEL DETAILS - PACKAGE SUBSTATION AND MAIN UNITS
S02-2-6-38	MARK 3 SUBSTATION CONDUIT LOCATION STANDARD JIG
S02-2-6-41	CIVIL FOUNDATION SLAB MK3 PACKAGE SUBSTATION PRE-CAST SLAB
S02-2-6-37_2	CIVIL MK3 PACKAGE SUBSTATION CABLE ENTRY AND FOUNDATION DETAILS SETOUT DRAWING - SHEET 2 OF 4

						DES	B.VDS	POWER STANDARD DRAWING			
						DRN	CWM	CIVIL, MK3 PACKAGE SUBSTATION			
						CKD	I.B.	CABLE ENTRY AND FOUNDATION DETAILS WITH			
						APPD	I.B.	MK 2 SLAB			
						SCALE	AS SHOWN	SETOUT DRAWING			
						ISSUED	Sep 2017	A3	DRAWING NUMBER	S02-02-06-42	AMD T
						ALL DIM. IN mm					
						DRAFTING STANDARD TO A.S.1100			CAD PRODUCT - DO NOT AMEND MANUALLY		
1	TITLEBLOCK & DRAWING NUMBER FORMATTED					K.T.	FEB'19	C.C.	C.C.		
0	ISSUED FOR CONSTRUCTION					CWM	AUG'17	I.B.	I.B.		
NO	DESCRIPTION					DRN	DATE	CKD	APPD		
AMENDMENTS											

