



ITEM 1: CROSSARM STEEL STOCK CODE 291641  
 MATERIAL: 100 X 100 X 6 SHS.

THIS ITEM REPLACES:  
 TIMBER TERMINATION CROSSARM SHOWN ON STD DRG NO S01-01-02-04, ITEM 1  
 TIMBER INTERMEDIATE & ANGLE SUSPENSION CROSSARM SHOWN ON STD DRG NO S01-01-02-04, ITEM 2.  
 TIMBER HIGH IMPULSE CROSSARM SHOWN ON STD DRG NO S01-01-02-08, ITEM 1

- NOTES:
- CROSSARM IS TO BE MADE OF 6mm SQUARE HOLLOW SECTION (DURAGAL).
  - CROSSARM IS NOT TO HAVE ANY ANTI-VERMIN END CAPS INSTALLED.
  - ORIGINAL SHACKLE STRAP IS TO BE REMOVED AND A GALVANISED REPLACEMENT TO BE INSTALLED. STOCK CODE 9530.

SUPERSEDED

NO	DESCRIPTION	DRN	DATE	CKD	APPD
2.	SUPERSEDED BY S01-01-02-21	K.I.	SEP'06	R.S.	S.C.
1.	MATERIAL CORRECTED FROM 5mm RHS TO 6mm SHS. NOTES ADDED.	RGI	NOV'99	FRR	FRR
AMENDMENTS					



DES	-	N.T. STANDARD DRAWING		
DRN	G.L.	CROSSARM, STEEL REPLACEMENT FOR TIMBER TERMINATION, INTERMEDIATE, ANGLE SUSPENSION & HIGH IMPULSE		
CKD	gmck/N.S.			
APPD	B.KENT			
SCALE	1:20			
ISSUED	MAY'91	A3	DRAWING NUMBER	S01-01-02-09
ALL DIM. IN mm U.N.O.				
DRAFTING STANDARD TO AS 1100			CAD PRODUCT— DO NOT AMEND MANUALLY	AMDT