


**NOTES**

- All welding and joint preparation to be in accordance with AS1554. All welds to be deslagged & wire brushed. All steelwork to be hot dip galvanized in accordance with AS1650.
- All threads are to be clean & workable after hot dip galvanizing

NO	DESCRIPTION	DRN	DATE	CKD	APPD
1	CHANGED TO 'NOT FOR NEW CONSTRUCTION'	R.A.	AUG'21	C.C.C	A.N.
AMENDMENTS					



DES	A. WHYTE	POWER STANDARD DRAWING	
DRN	N. HORDERN	FUSED DISTRIBUTION PILLAR STEELWORK ASSEMBLY AND DETAILS	
CKD	S. SAWYER		
APPD	F. ROBSON	A3	DRAWING NUMBER S02-01-03-07
SCALE	AS SHOWN		
ISSUED	APR'01		
ALL DIM. IN mm		DRAFTING STANDARD TO A.S.1100	
		CAD PRODUCT - DO NOT AMEND MANUALLY	

