









**STEELWORK NOTES:**

1. ALL MATERIALS SHALL BE IN ACCORDANCE WITH AS 3678 AND AS 3679.
2. ALL WELDING AND WELD PREPARATION SHALL BE IN ACCORDANCE WITH AS 1554.
3. ALL ROUGH OR BURRED EDGES ARE TO BE DRESSED CLEAN.



**ITEM 1: TYPE B POLE**  
STRONG SIDE  
ITEM NUMBER: 504549

**ITEM 2: TYPE C POLE**  
STRONG SIDE  
ITEM NUMBER: 504567

**ITEM 3: TYPE D POLE**  
STRONG SIDE  
ITEM NUMBER: 504568

**ITEM 4: CABLE PROTECTION PLUS BACKING**  
PLATE FOR WEAK SIDE ALL POLES  
ITEM NUMBER: 504569

8	UPDATED DEPTH DIMENSIONS ON ALL ITEMS. ADDED ITEM REFERENCES.	A.N.	DEC'21	A.N.	B.V.
7	AMEND DIMENSION ITEM NUMBER 504568	H.E.	DEC'20	H.E.	B.V.
6	DESIGN CHANGE AND ADDITIONAL VERSIONS	C.W.M.	APR'20	B.V.	B.C.
5	ITEM NUMBER ADDED	C.W.M.	FEB'20	B.V.	B.C.
4	TITLEBLOCK & DRAWING NUMBER FORMATTED	K.T.	DEC'18	C.C.	C.C.
3	DIMENSIONS AND MATERIAL	K.I.	SEP'08	A.T.	S.C.
2	REDUCE LENGTH BY 1m	K.I.	AUG'05	C.C.	C.C.
1	REDRAWN IN CAD	A.D.	MAY'98	R.I.	F.R.
NO	DESCRIPTION	DRN	DATE	CKD	APPD
AMENDMENTS					



DES	B.CHEUNG	POWER STANDARD DRAWING			
DRN	C.McLAREN	LINE HARDWARE CABLE PROTECTION CHANNEL			
CKD	B.CHEUNG				
APPD	B.CHEUNG				
SCALE	AS SHOWN				
ISSUED	APR 2020	A3	DRAWING NUMBER	S01-01-04-30	
ALL DIM. IN mm				CAD PRODUCT - DO NOT AMEND MANUALLY	
DRAFTING STANDARD TO A.S.1100					