



BARE L.V. CONDUCTOR INSULATING MAT
(ITEM NUMBER:7641)

MATERIAL

PVC 'LAYFLAT HOSE' #152mm-ORANGE COLOUR,OR OR PWE APPROVED
 PVC 'LAYFLAT HOSE' #152mm-BLUE COLOUR EQUIVALENT
 CUT ONE SIDE LONGITUDINALLT - REMOVE THE CURLED EDGES

TOUCH TAPE 25mm 'VELCRO CIRC CRAC' - BLACK
 STITCH TAPE TO INSIDE FACE OF HOSE SO MAT
 CAN BE FOLDED LENGTHWISE OR ACROSS FOLD AND
 TO REVERS SIDE AS DETAILED

TOLERANCE:

+5mm UNLESS SHOWN OTHERWISE

PROFF TEST:

TESTING TO COMPLY WITH AS2978

3	TITLEBLOCK & DRAWING NUMBER FORMATTED	K.T.	DEC'18	C.C.	C.C.
2	REFERENCE TO AS2978 ADDED	C.C.	JAN'11	A.T.	S.C.
1	REDAWN IN CAD	C.C.	OCT'10	A.T.	S.C.
NO	DESCRIPTION	DRN	DATE	CKD	APPD
AMENDMENTS					



DES	A.TAYLOR	POWER STANDARD DRAWING		
DRN	C.COPPINS	EQUIPMENT ELECTRICAL INSULATING MAT BARE L.V. CONDUCTORS		
CKD	A.TAYLOR			
APPD	A.TAYLOR			
SCALE	1:5			
ISSUED	OCT'10	A3	DRAWING NUMBER	S01-01-08-07
ALL DIM.	IN mm			
DRAFTING STANDARD TO A.S.1100			CAD PRODUCT - DO NOT AMEND MANUALLY	

