



**STEELWORK NOTES**

1. ALL WORKMANSHIP AND MATERIALS SHALL BE IN ACCORDANCE WITH AS3678.
2. ALL WELDING AND WELD PREPARATION SHALL BE IN ACCORDANCE WITH AS1554. FILLET WELDS TO BE 6 mm, UNLESS NOTED OTHERWISE.
3. ALL ROUGH OR BURRED EDGES ARE TO BE DRESSED CLEAN.

7	1	POLE TOP UNIT - TYPE 'd'	-	S01-02-02-01
6	1	POLE TOP UNIT - TYPE 'A'	-	S01-02-02-02
5	2	END PLATE - 65x6 FLAT x 125.	-	-
4	1	STRUT - DIAGONAL 100x50x3.5 RHS x 2350.	-	-
3	1	STRUT - VERTICAL 100x50x3.5 RHS x 1265.	-	-
2	1	CROSSARM - LV - 125 x 65 TFC x 2330.	-	-
1	1	CROSSARM - HV	9597	S01-01-02-02
TAG No	QTY.	DESCRIPTION	STOCK CODE	DRG REF

A.B. MATERIAL SCHEDULE

DES	gmck	POWER STANDARD DRAWING	
DRN	N.STUBBS	POLE TOP UNITS	
CKD	B.T.KENT	HV/LV OFFSET CONSTRUCTION	
APPD	AS SHOWN	GENERAL ARRANGEMENT	
SCALE	NOV'92		
ISSUED		A3	DRAWING NUMBER S01-02-02-19
ALL DIM.	IN mm		
DRAFTING STANDARD TO A.S.1100		CAD PRODUCT - DO NOT AMEND MANUALLY	

NO	DESCRIPTION	DRN	DATE	CKD	APPD
2	SUPERSEDED	A.T.	DEC'12	B.C.	B.C.
1	NOTE 1 AMENDED	J.A.L.	JAN'97	A.G.B.	F.R.R.
AMENDMENTS					

**PowerWater**  
NORTHERN TERRITORY

2  
AMDT