



DETAIL 'B'

NOTES :

1. ALL WELDS SHALL BE 6mm CONTINUOUS FILLET.
2. ALL WORKMANSHIP AND MATERIALS SHALL BE IN ACCORDANCE WITH THE RELEVANT SAA CODES.

U P E

ITEM	QTY.	DESCRIPTION
4	AS REQ.	BRACKET - SQUARE EDGE FLAT
3	2	1" PLUGS
2	2	1" GATE VALVE OR BALL VALVE
1	AS REQ.	1" STEEL PIPE

NO	DESCRIPTION	DRN	DATE	CKD	APPD
3	REDRAWN ON CAD AND BALL VALVE ADDED	A.S.	NOV '04	R.C.	C.F.
AMENDMENTS					

PowerWat r

DES	G. Mc SHANAG	POWER STANDARD DRAWING	
DRN	A. SCHMID	SUBSTATIONS PACKAGE TRANSFORMER OIL PIPES	
CKD	R. CLEOPAS		
APPD	C. FOO		
SCALE	N.T.S.	A3	DRAWING NUMBER S02-01-07-02
ISSUED	NOV '04		
ALL DIM.	IN mm	CAD PRODUCT - DO NOT AMEND MANUALLY	

AMDT 3