


SIDE VIEW

SCALE 1:50



ITEM 3 POLE DATA NAMEPLATE (EXAMPLE)

SCALE - NTS

NOTES

- CENTRE OF GRAVITY / LIFTING POINT SHALL BE MARKED ON EACH SECTION
- TWO PIECE SPLICED POLE IS NOT THE PREFERRED OPTION FOR GREENFIELD SITES
- REFER TO S01-02-01-69 FOR INSTALLATION DETAILS
- APPLICATION OF THIS POLE IS RESTRICTED FOR INTERNAL POWER NETWORKS USE ONLY. FOR OTHER APPLICATIONS AND APPROVALS, CONTACT POWER NETWORKS STANDARDS
- POLES TO COMPLY WITH PWC DOCUMENT STSP 01-002
- ALL WELDS TO BE 6mm FILLET CONTINUOUS WELD UNO EXCEPT ANTICLIMB PLATE WHICH IS TO HAVE 6mm FILLET 150mm LONG AT BOTH ENDS AND CENTRE
- FOR SPLICE DETAILS REFER TO DRG S01-01-01-40

TWO PIECE SPLICED POLE 16.5D - ITEM NUMBER: 505076

TOTAL MASS 16.5D - TOP - 1102Kg

TOTAL MASS 16.5D - BOTTOM - 502Kg

ITEM	QTY. 16.5D	MATERIAL DESCRIPTION
1	2	670 X 250 X 25 FMS FLANGE PLT 26 DIA HOLES, REFER DRG S01-01-01-40
2	4	218 X 200 X 8 FMS STIFFENER PLT. REFER DRG S01-01-01-40
3	2	POLE DATA NAME PLATE
4	-	REFER DRG S01-01-01-14 FOR ALL OTHER POLE MATERIALS

						DES B.VANDERSTELT		POWER STANDARD DRAWING	
						DRN P.GUNA		TWO PIECE SPLICED POLE LINE 16.5D BOLTED CONNECTIONS TYPE	
						CKD P.BHATTARAI			
						APPD B.VANDERSTELT		A3	
						SCALE 1:50			
						ISSUED MAR'24		DRAWING NUMBER S01-01-01-43	
						ALL DIM. IN mm			
						DRAFTING STANDARD TO A.S.1100		CAD PRODUCT - DO NOT AMEND MANUALLY	
								AMDT	



NORTHERN TERRITORY

0	ISSUED FOR CONSTRUCTION	P.G.	MAR'24	P.BH.	B.V.
NO	DESCRIPTION	DRN	DATE	CKD	APPD
AMENDMENTS					