



NOTES

- 1 NEUTRAL BOND TO BE CONTINUOUS THROUGH PIERCING CONNECTOR INTO NEUTRAL LINK IN JUNCTION BOX.
- 2 35mmsq Cu ACTIVE TAILS TO BE PHASE COLOURED WITH TAPE BEFORE CONNECTION TO JUNCTION BOX.
- 3 SERVICES TO BE TAKEN FROM JUNCTION BOX SEE DRG. S04-01-02-15
- 4 M.E.N. TO BE FITTED SEE DRG. S04-02-03-01
- 5 PIERCING CONNECTOR GREASE CAPS TO BE FITTED OVER ABC.
6. SURGE DIVERter BRACKET TO BE POWER FASTENED TO POLE AND M.E.N. STRAP.

ITEM	QTY	DESCRIPTION	ITEM No	DRG REF
11	3	CONNECTOR, PIERCING 95/35	197723	S04-01-02-15
10	-	JUNCTION BOX	206169	S04-01-03-04
9	1	BRACKET - SURGE DIVERter	214932	S01-01-04-27
8	3	SURGE DIVERter LV	206664	S01-01-04-20
7	1	LUG COMPRESSION 35mmsq	156240	
6	-	CABLE Cu PVC 35mmsq BLACK	1586	-
5	4	CONNECTOR, PIERCING 95/95	197715	S04-01-02-15
4		CABLE LV ABC, 4x95mmsq	197665	S04-01-01-01
3	1	CLAMP STRAIN 4X95mmsq	197707	S04-01-02-11
2b	1	HOOK BOLT M16	197731	S04-01-02-07
2a		HOOK BOLT M16 NON-BREAKAWAY ASSEMBLY		S04-01-02-07
1	1	BRACKET HOOK MOUNTING	203679	S04-01-02-02
ITEM	QTY	DESCRIPTION	ITEM No	DRG REF
MATERIAL SCHEDULE				

VIEW
Scale 1:10

ELEVATION
Scale 1:10

- 3 SUPERSEDED (REFER DRG Nos: S04-02-04-05 and S04-02-01-26) AND CORRECTED DRAWING TITLE
- 2 TITLEBLOCK & DRAWING NUMBER FORMATTED
- 1 DRAWING REF FPR ITEM No 9 REVISED, NOTE 6 AMENDED

NO	DESCRIPTION	DRN	DATE	CKD	APPD
	AMENDMENTS				

P.G. SEP'25 B.B. B.V.
K.T. DEC'19 C.C. C.C.
G.McK MAY'91 - N.S.

PowerWater
NORTHERN TERRITORY

DES B.T.KENT
DRN H.T./gmck
CKD G. SCHUBERT
APPD B.T.KENT
SCALE AS SHOWN
ISSUED SEPT '89
ALL DIM. IN mm
DRAFTING STANDARD TO A.S.1100

POWER STANDARD DRAWING

**CABLE TERMINATION
LV-ABC
TERMINATION & SURGE DIVERTERS**

A3 **DRAWING
NUMBER** S04-02-04-01

CAD PRODUCT - DO NOT AMEND MANUALLY

3
AMDT