



VIEW
Scale 1: 10

ELEVATION
Scale 1: 10

NOTES

- 1 NEUTRAL BOND TO BE CONTINUOUS THROUGH PIERCING CONNECTOR INTO NEUTRAL LINK IN JUNCTION BOX.
- 2 35mmsq Cu ACTIVE TAILS TO BE PHASE COLOURED WITH TAPE BEFORE CONNECTION TO JUNCTION BOX.
- 3 SERVICES TO BE TAKEN FROM JUNCTION BOX SEE DRG. S04-01-02-15
- 4 M.E.N. TO BE FITTED SEE DRG. S04-02-03-01
- 5 PIERCING CONNECTOR GREASE CAPS TO BE FITTED OVER ABC.
6. SURGE DIVERter BRACKET TO BE POWER FASTENED TO POLE AND M.E.N. STRAP.

ITEM	QTY	DESCRIPTION	ITEM No	DRG REF
11	3	CONNECTOR, PIERCING 95/35	197723	S04-01-02-15
10	-	JUNCTION BOX	206169	S04-01-03-04
9	1	BRACKET - SURGE DIVERter	214932	S01-01-04-27
8	3	SURGE DIVERter LV	206664	S01-01-04-20
7	1	LUG COMPRESSION 35mmsq	156240	
6	-	CABLE Cu PVC 35mmsq BLACK	1586	-
5	4	CONNECTOR, PIERCING 95/95	197715	S04-01-02-15
4		CABLE LV ABC, 4x95mmsq	197665	S04-01-01-01
3	1	CLAMP STRAIN 4x95mmsq	197707	S04-01-02-11
2b	1	HOOK BOLT M16	197731	S04-01-02-07
2a	1	HOOK BOLT M16 NON-BREAKAWAY ASSEMBLY		S04-01-02-07
1	1	BRACKET HOOK MOUNTING	203679	S04-01-02-02
ITEM	QTY	DESCRIPTION	ITEM No	DRG REF

MATERIAL SCHEDULE

2	TITLEBLOCK & DRAWING NUMBER FORMATTED	K.T.	DEC'19	C.C.	C.C.
1	DRAWING REF FPR ITEM No 9 REVISED, NOTE 6 AMENDED	G.McK	MAY'91	-	N.S.
NO	DESCRIPTION	DRN	DATE	CKD	APPD
AMENDMENTS					



DES	B.T.KENT	POWER STANDARD DRAWING			
DRN	H.T./gmck	SAG & TENSION TABLES			
CKD	G. SCHUBERT	LV - ABC			
APPD	B.T.KENT	STRINGING TABLE			
SCALE	AS SHOWN	8kN TENSION			
ISSUED	SEPT '89	A3	DRAWING NUMBER	S04-02-04-01	
ALL DIM.	IN mm				
DRAFTING STANDARD TO A.S.1100		CAD PRODUCT - DO NOT AMEND MANUALLY		AMDT	