



ITEM	STOCK CODE	CABLE SIZE	VOLTAGE	TYPE	RAYCHEM PART No	TAIL LENGTH	SIGMAFORM PART No	TAIL LENGTH
1	15883	240 sq.mm COPPER	22 kV	OUT DOOR	EPKT-24D3 MOH4	1200	SAT0-22-185/240-B3-1200	1200
2	3590	300 sq.mm	11 kV	INDOOR	EPKT-17D3MIH2	650	SAT1-11-300-B3-650	650
3	7609	400 sq.mm ALUMINIUM	11 kV	OUT DOOR	EPKT-17D3MOH4	1200	SAT0-11-400-B3-1200	1200
4	7583	400 sq.mm ALUMINIUM	11 kV	INDOOR	EPKT-17D3MIH2	650	SAT1-11-400-B3-650	650
5	3574	120 sq.mm COPPER	22 kV	OUT DOOR	EPKT-24C3MOH4	1200	SAT0-22-120-B3-1200	1200
6	3566	120 sq.mm COPPER	22 kV	INDOOR	EPKT-24C3MIH2	650	SAT1-22-120-B3-650	650
7	3558	25 sq.mm COPPER	22 kV	OUT DOOR	EPKT-24B3MOH4	1200	SAT0-22-25/70-B3-1200	1200
8	3541	25 sq.mm COPPER	22 kV	INDOOR	EPKT-24B3MIH2	650	SAT1-22-25/70-B3-600	600

NOTES :

- ALL TERMINATION KITS TO CONTAIN INSTALLATION INSTRUCTIONS.
- MATERIALS TO BE HEAT-SHRINKABLE, NON-TRACKING, EROSION RESISTANT, ELECTRICALLY INSULATED, POLYMERIC.
- REFER TO PA.W.A. TECHNICAL SPECIFICATION STS 038 FOR GENERAL REQUIREMENTS AND CONDITIONS OF SERVICE.

7	3	3	H.V. LUG SEALING SLEEVES COATED INTERNALLY WITH 'A' ADHESIVE
6	6	6	H.V. TUBING 50 mm LENGTHS 3 WAY SHED PACKING 25 sq.mm ONLY
5	1	1	MOULDED GLOVE
4	1	1	H.V. 3 WAY SHED
3	6	9	H.V. SINGLE SHED
2	3	3	STRESS GRADE TUBING
1	3	3	OUTER TUBING

TAG No	11 kV	22 kV	DESCRIPTION
	QTY.		
MATERIAL SCHEDULE			

12 SUPERSEDED
 11 REDRAWN ON MICROSTATION. SIGMAFORM PART No ADDED.
 10 NOTE 1 AMENDED, NOTE 3 ADDED.
 TITLE AND DRAWING No CHANGED

A.T.	DEC' 12	B.C.	B.C.
J.A.L	DEC' 95	A.T.	P.J.D
Q.L.F	MAY' 88	-	-
DRN	DATE	CKD	APPD

PowerWater
 NORTHERN TERRITORY

DES	R.HAIGH	POWER STANDARD DRAWING	
DRN	R.BUZZO	CABLE JOINTING & TERMINATIONS	
CKD	K.CHHIT	TERMINATION KITS 11 kV/22 kV	
APPD	B.KENT	SCREENED PILC CABLES	
SCALE	N.T.S.	HEAT-SHRINKABLE	
ISSUED	NOV' 85	A3	DRAWING NUMBER S02-01-02-12
ALL DIM. IN mm			
DRAFTING STANDARD TO A.S.1100		CAD PRODUCT - DO NOT AMEND MANUALLY	



NO	DESCRIPTION	DRN	DATE	CKD	APPD
AMENDMENTS					