



NOTES:

1. EARTH ELECTRODES ARE TO BE PLACED DIRECTLY BELOW CENTERLINE OF OVERHEAD CONDUCTORS.
2. COMBINED EARTH ELECTRODES AND POLE FOOTING EARTH RESISTANCE TO BE 30 OHM MAX WHEN ALL MEN AND CMEN CONNECTIONS ARE REMOVED.
3. COMBINED EARTH GRID RESISTANCE IS TO BE 1 OHM MAX WHEN ALL MEN AND CMEN CONNECTIONS ARE MADE.
4. IF ABOVE VALUES CAN NOT BE ACHIEVED CONTACT THE PROJECT MANAGER.

3	DRIVING HEAD TO SUIT 14MM DIAMETER STAINLESS STEEL EARTH ROD	414062
2	COUPLING TO SUIT 14MM DIAMETER STAINLESS STEEL EARTH ROD	414061
1	316 GRADE STAINLESS STEEL EARTH ROD, 1500MM LONG, 14MM DIAMETER	414060
ITEM	DESCRIPTION	ITEM NUMBER

MATERIAL SCHEDULE

						DES A.TAYLOR		POWER STANDARD DRAWING	
						DRN C.COPPINS		EARTHING EARTHING ROD AND ACCESSORIES	
						CKD A.TAYLOR			
						APPD S.C.			
						SCALE 1:1		A3 DRAWING NUMBER S01-01-05-01	
						ISSUED JAN'11			
						ALL DIM. IN mm		CAD PRODUCT - DO NOT AMEND MANUALLY	
						DRAFTING STANDARD TO A.S.1100			
						 NORTHERN TERRITORY			
8	TITLEBLOCK & DRAWING NUMBER FORMATTED				K.T.	DEC'18	C.C.	C.C.	
7	ROD CHANGED TO STAINLESS STEEL				J.C.	NOV'11	A.T.	S.C.	
6	REDRAW IN CAD				C.C.	JAN'11	A.T.	S.C.	
NO	DESCRIPTION				DRN	DATE	CKD	APPD	
AMENDMENTS									