

16	1	BOLT M12 x 50		114470	36	1	SIGN DANGER EARTHING 10m	S25-3-2-3	NEW
15	1	MOUNTING BRACKET	S1-1-4-19	251926	35	1	SIGN DANGER 19000volts	S25-3-2-1	NEW
14	1	BOLT M12 x 50		114470	34	1	U-BEND, GUY	S1-1-4-8	9522
13	1	INSULATING BRACKET	S1-1-4-19	249466	33		CU CONDUCTOR, 19/2.14, 70sq.mm	S1-1-5-5	9803
12	1	SURGE DIVERTER, 33kV (cw bird cap & reflector)	S1-1-4-19	249441	32		LUG, COPPER COMPRESSION 19/2.14 70sq.mm	S1-2-3-11	5512
11	1	LUG, 35sq.mm		282277	31	1	CABLE PROTECTION CHANNEL & FIXINGS	S1-1-4-30	
10		Cu DROPPER CABLE, 35sq.mm PE/PVC, (19/1.53, 17mmDIA)	S2-1-1-5	9092	30	2	LV SURGE DIVERTER	S1-1-4-20	10041
9	1	CLAMP LIVE LINE	S1-1-4-17	2139	29	1	BRACKET LV SURGE DIVERTER	S1-1-4-27	214932
8	1	CLAMP, ALUMINIUM BAIL	S1-1-4-10	5603	28		S/STEEL BAND-IT STRAP		NOT ON STOCK
7	1	INSULATOR STUD, M24 (cw nuts, spring & flat washers)	S25-2-2-2	114629	27		POLYETHYLENE PIPE, DN40 PE80 PN6.3		NOT ON STOCK
6	-	TIE WIRE	S1-2-1-2	8839	26		70sq.mm Cu PE/PVC CABLE		9399
5	1	LINE POST INSULATOR, 33kV (refer Morlynn drg no H11461)			25	1	M12 X 40 BOLT		114462
4	1	INSULATOR MOUNTING BRACKET (150 PFC welded to pole)	S25-2-2-2	NEW	24	1	Cu STRAP 25 X 3mm	S1-1-5-5	9837
3	2	PREFORMED DEADEND	S1-1-4-18	3335	23	1	TANK EARTH BOLT		
2	-	CONDUCTOR 3/2.75 SC/AC OR 3/4/2.50ACSR/GZ		8748/1610	22	1	TRANSFORMER, DISTRIBUTION		
1	1	13.5C POLE	S1-1-1-2	11122	21	1	LUG, 35sq.mm		282277
					20	1	Cu DROPPER CABLE, 35sq.mm PE/PVC,	S2-1-1-5	9092
					19	1	ISOLATING SWITCH, 36kV EDO (cw parallel groove clamps & mounting bracket)		NEW
					18	-	Cu STRAP 25 x 3mm	S1-1-5-5	9837
					17	1	EARTH DISCONNECTOR		249458

DES	M. BOCK	POWER STANDARD DRAWING	
DRN	R. INNES	SINGLE WIRE EARTH RETURN DISTRIBUTION TRANSFORMER POLE MATERIALS SCHEDULE	
CKD	S. SAWYER	A3	DRAWING NUMBER
APPD	F. ROBSON		
SCALE	NO SCALE	S25-1-1-04	
ISSUED	27/10/97	DRAFTING STANDARD TO A.S.1100	
ALL DIM. IN mm		CAD PRODUCT - DO NOT AMMEND MANUALLY	
		AMD T	

2
1
ITEM 32 CHANGED Q/LUG TO COMPRESSION.
APPROVED FOR CONSTRUCTION.

K.I. FEB'05 C.C. C.C.
RGI SEP'99 MWB FRR

NO	DESCRIPTION	DRN	DATE	CKD	APPD
	AMENDMENTS				