


NOT FOR USE WITH FIRE HOSE REELS



1. ALL DIMENSIONS IN MILLIMETRES UNLESS NOTED OTHERWISE.
2. COPPER ALLOY SHALL BE DEZINCIFICATION RESISTANT (DR) TO AS2345.
3. USE SILVER BRAZING ALLOY (MIN 2% SILVER TO AS1167.1) FOR ALL CAPILLARY JOINTING OF COPPER PIPES AND FITTINGS OR ALTERNATIVELY, FOR HORIZONTAL JOINTS ABOVE GROUND PRESS FITTINGS MAY BE USED.
4. THE METER ASSEMBLY SHALL BE HORIZONTAL.
5. ONLY PWC (OR ITS AUTHORISED CONTRACTORS) ARE PERMITTED TO TAP EXISTING, IN-SERVICE (LIVE) MAINS OR MAINS THAT HAVE BEEN HYDROSTATICALLY TESTED. WITHIN LICENSED AREAS AND UPON PAYMENT OF THE NECESSARY FEES, PWC WILL PERFORM TAPPING OF LIVE MAINS, HOWEVER, EXCAVATION, ALL MATERIALS AND INSTALLATION SHALL BE SUPPLIED BY THE CONTRACTOR.
6. ALL PIPES, VALVES AND FITTINGS MUST BE WATER MARK APPROVED.
7. ON COMPLETION OF WATER SERVICE, PROVIDE BRASS PLUG FITTED TO METER TAP OUTLET.
8. NON-METALLIC MATERIALS AND FITTINGS SHALL NOT FORM PART OF WATER METER ASSEMBLY.
9. FOR DUAL SERVICE, BRANCH PIPE SHALL ALWAYS BE ON THE LEFT OF THE MAIN SERVICE PIPE WHEN FACING BOUNDARY AS SHOWN ON THE DRAWING. FOR LOTS MORE THAN 1500 sq.m IN AREA, IDENTIFY EACH PROPERTY OFFTAKE WITH A 50 x 50 x 2 ALUMINIUM PLATE IDENTIFICATION TAG WITH PROPERTY NUMBER STAMPED IN 10mm HIGH LETTERS. WIRE TAG TO METER TAP WITH 3mm GALVANISED WIRE.
10. WHERE A SINGLE PROPERTY IS CONNECTED TO THE WATER SERVICE (EG. NO BRANCH PIPE TO SECOND PROPERTY), DN20 PIPEWORK MAY BE USED FROM MAIN TO PROPERTY BOUNDARY IF THE PROPERTY IS LESS THAN 900 sq.m IN AREA AND NO ROAD CROSSING IS REQUIRED, OTHERWISE USE DN25 PIPEWORK AND REDUCE TO DN20 COPPER TUBE APPROXIMATELY 675mm BEFORE SWEEPED BEND TO UPSTAND AND METER TAP - USE BRAZED CAPILLARY REDUCER.
11. BACKFLOW CERTIFIED PLUMBER IS REQUIRED TO DETERMINE THE RISK OF CONTAMINATION OF THE POTABLE WATER SUPPLY DUE TO CROSS CONNECTIONS, REFER AS/NZS3500.1. A TESTABLE BACKFLOW PREVENTION DEVICE SHALL BE FITTED FOR MEDIUM OR HIGH HAZARD PROPERTIES.
12. TO ENSURE INTEGRITY AND STABILITY OF THE WATER METER INSTALLATION ANY CONNECTION TO THE COPPER RISER OF THE CUSTOMER'S SERVICE AND THE FIRST UNDERGROUND 1000mm OF THE CUSTOMER'S SERVICE MUST USE A BRAZED JOINTS COMPLYING WITH NOTE 3.
13. NO OTHER UTILITY SERVICES (EG. COMMUNICATIONS, POWER, SEWER) TO BE INSTALLED BETWEEN WATER SERVICE, METER AND PROPERTY BOUNDARY.
14. MINIMUM CLEARANCE TO OTHER SERVICES SHALL BE 300mm.
15. WHERE SIDE BOUNDARY OF PROPERTY ADJACENT TO WATER METER IS NOT PERPENDICULAR TO ROAD RESERVE BOUNDARY, INSTALL WATER METER PARALLEL TO SIDE BOUNDARY.
16. NUT AND TAILS FOR METER INSTALLATION SUPPLIED BY PWC.
17. PRESSURE TEST WATER SERVICE AT 1000kPa FOR 30 MINUTES (NO PRESSURE LOSS PERMITTED) USING WATER CHLORINATED TO A MINIMUM CHLORINE CONCENTRATION OF 25mg/L (REFER PWC WATER SERVICES GUIDELINE FOR DISINFECTION OF SUBDIVISIONS AND WATER SERVICE CONNECTIONS FROM 20mm AND GREATER). ENSURE PIPEWORK IS FLUSHED OUT AFTER THE TEST FOR A MINIMUM OF FIVE MINUTES.
18. SWEEPED BEND TO BE FORMED USING PIPE BENDER OR BENDING SPRING WITH A BEND RADIUS GREATER THAN FIVE TIMES THE OUTSIDE DIAMETER OF THE COPPER TUBE.
19. WHERE A CONCRETE PATH OR SLAB IS CAST UNDER THE METER, PROVIDE A BREAK-OUT SECTION BETWEEN 600x300 AND 1500x600 FOR FUTURE ACCESS TO BURIED PIPEWORK.
20. WATER SERVICES SHALL BE CONSTRUCTED TO W1-2-21B TRENCH DETAIL 8.

3	NOTE 20 ADDITION 2025.	JC	JULY'25	JC	DC
2	GENERAL AMENDMENTS 2020.	PW	JULY'20	JR	DC
1	GENERAL UPDATE.	AW	JUNE'18	JR	DC
0	ISSUED FOR INFORMATION.	AW	APRIL'13	RJ	RJ
NO	DESCRIPTION	DRN	DATE	CKD	APPD
AMENDMENTS					



PowerWater

NORTHERN TERRITORY

DES	-	WATER STANDARD DRAWING			
DRN	AW				
CHK	RJ				
APPD	RJ				
SCALE	N.T.S.	SERVICES			
ISSUED	APRIL 2013	DN20 WATER SERVICE - COPPER			
ALL DIM. IN mm		LOW HAZARD			
DRAFTING STANDARD TO A.S.1100		A3	DRAWING NUMBER	W1-1-01A	3
CAD PRODUCT - DO NOT AMEND MANUALLY					AMD