



**NOTES**

- 1. PROOF LOAD : 4.4 kN  
SWL : 200 kg
- 2. ITEM TO BE PURCHASED FROM ELECTRICITY TRUST OF SOUTH AUSTRALIA  
PART NUMBER-KL 5500

11	SNAP HOOK MOXHAM Mk 10 APPROVED EQUIV FOR ROPE LANYARD THUMB PADS REMOVED
10	NYLON THIMBLE TO SUIT $\phi$ 10mm ROPE
9	SPLICED END TO ROPE
8	CRIMP SLEEVES (ALUMINUM) TO SUIT $\phi$ 12mm ROPE
7	ROPE BRAIDED POLYESTER LENGTH 13m
6	CONTROLLED DESCENT DEVICE
5	RAPID ADJUSTOR
4	SNAP HOOK MOXHAM Mk 30 WITH MK 2 LATCH OR APPROVED EQUIVALENT
3	PVC SLEEVING $\phi$ 18mm TO PROTECT STRANDS OF ROPE
2	POLYTHENE SILVER ROPE $\phi$ 16mm OVERALL LENGTH AFTER SPLICING 1.25m
1	SPLICED JOINT
ITEM	DESCRIPTION

ITEM 1-CONSTANT DESCENT  
DEVICE  
(ITEM NUMBER - 13789)

						DES	POWER STANDARD DRAWING				
						DRN	EQUIPMENT				
						CKD	POLE TOP RESCUE				
						APPD	CONSTANT DESCENT DEVICE				
						SCALE					
						ISSUED					
						ALL DIM. IN mm	A3	DRAWING NUMBER	S01-01-08-05	1 AMDT	
						DRAFTING STANDARD TO A.S.1100	CAD PRODUCT - DO NOT AMEND MANUALLY				
1	TITLEBLOCK & DRAWING NUMBER FORMATTED					K.T.	DEC'18	C.C.	C.C.		
0	REDRAWN IN CAD					C.C.	OCT'10	A.T.	S.C.		
NO	DESCRIPTION					DRN	DATE	CKD	APPD		
AMENDMENTS											

**PowerWater**

NORTHERN TERRITORY