


ITEM REF.	CONDUCTOR		COMPRESSION LINK			COMPRESSION DIE		
	CONDUCTOR	CONDUCTOR O.D.	LINK I.D. DIM. 'A'	LINK LENGTH DIM. 'L'	LINK ITEM NUMBER	DIE HEX A/F	NUMBER OF CRIMPS PER END REQ.	DIE ITEM NUMBER
1	FLUORINE/LIBRA 7/3.00	9.00	9.60	70	503518	18	1	503645
2	HYDROGEN/MERCURY 7/4.50	13.50	14.60	110	503511	18.3	3	503643
3	NEON/PLUTO 19/3.75	18.75	20.20	146	503512	25.4	3	503640
4	APPLE 6/1/3.00	9.00	9.60	70	503518	18	1	503645
5	BANANA 6/1/3.75	11.30	12.60	85	503502	16.8	2 OVERLAP	-
6	CHERRY 6/4.75/7/1.60	14.30	16.00	150	503969	22	2	504040
7	RAISIN 3/4/2.50	7.50	7.90	58	503970	13.2	1	504042
8	SC/AC 3/2.75	5.93	7.90	58	503970	13.2	1	504042



**NOTES:**

1. FITTINGS ARE TO CONFORM WITH RELEVANT SECTIONS OF AS1531 AND BE SUITABLE FOR USE WITH CONDUCTORS COMPLYING WITH AS1531 AND AS3607.
2. FITTINGS TO BE CLEARLY MARKED WITH CONDUCTOR TYPE, CRIMP SIZE AND CRIMPING POSITIONS.
3. FITTINGS TO BE DESIGNED FOR HEXAGONAL CRIMPING DIES USED IN 13T HYDRAULIC COMPRESSION TOOLS.
4. FITTINGS TO BE PRE-FILLED WITH JOINTING COMPOUND AND PLUGGED AT BOTH ENDS.
5. FITTINGS TO BE INDIVIDUALLY PACKED IN PLASTIC BAGS.

4 REFORMATTED TABLE AND ADDED DIMENSION, CONDUCTOR SIZES & DRAWING. 3 TITLEBLOCK & DRAWING NUMBER FORMATTED 2 STATUS CHANGED TO CURRENT 1 ITEMS 5-8, DIE STOCK CODES AMENDED 0 ISSUED FOR CONSTRUCTION	A.N. AUG'21 K.T. DEC'18 C.C. OCT'18 C.W.M. APR'17 A.T. NOV'16	A.N. B.C. C.C. C.C. B.C. B.V. B.C. B.C. I.B. B.C.	DES	B.CHEUNG	POWER STANDARD DRAWING	
			DRN	A.TAYLOR	LINE HARDWARE	
			CKD	I.BASHIR	SINGLE SLEEVE SPLICE	
			APPD	B.CHEUNG	NON TENSION	
AMENDMENTS			SCALE	N.T.S.	AAC, AAAC & ACSR CONDUCTORS	
			ISSUED	NOV 2016	A3	DRAWING NUMBER S01-01-04-54
			ALL DIM. IN mm			
			DRAFTING STANDARD TO A.S.1100		CAD PRODUCT - DO NOT AMEND MANUALLY	

