



SCALE 1:40

ITEM 3 POLE DATA NAMEPLATE DETAILS (EXAMPLE)

N.T.S.

NOTES

- 1. CENTRE OF GRAVITY / LIFTING POINT MUST BE MARKED ON EACH SECTION
- 2. TWO PIECE SPLICED POLE IS NOT THE PREFERRED OPTION FOR GREENFIELD SITES
- 4. REFER TO S01-02-01-69 FOR INSTALLATION DETAILS
- 5. APPLICATION OF THIS POLE IS RESTRICTED FOR INTERNAL POWER NETWORKS USE ONLY. FOR OTHER APPLICATIONS AND APPROVALS, CONTRACT POWER NETWORKS STANDARDS
- 6. POLES TO COMPLY WITH PWC DOCUMENT WITH STSP 01-002
- 7. ALL WELDS TO BE 6mm FILLET CONTINUOUS WELD UNO EXCEPT ANTICLIMB PLATE WHICH IS TO HAVE 6mm FILLET 150mm LONG AT BOTH ENDS AND CENTRE
- 8. FOR SPLICE DETAILS REFER TO DRG S01-01-01-40

TWO PIECE SPLICED POLE 13.5D - ITEM NUMBER: 503629

TOTAL MASS 13.5D - TOP - 881Kg TOTAL MASS 13.5D - BOTTOM - 453Kg

ITEM	QTY. 13.5D	MATERIAL DESCRIPTION
1	2	648 x 250 x 25 FMS. FLANGE PLT. 26 DIA HOLES, REFER DRG S01-01-01-40
2	4	218 x 200 x 8 FMS. STIFFENER PLT., REFER DRG S01-01-01-40
3	2	POLE DATA NAME PLATE
4	-	REFER DRG S01-01-01-13 FOR ALL OTHER POLE MATERIALS
	1 2 3 4	1TEM 2 1 2 2 4 3 2 4 -



_									
DES	J.NOY	'NAY	POWER STANDARD DRAWING						
DRN	A.TA`	YLOR	TWO PIECE SPLICED POLE						
CKD	I.BAS	HIR	LINE 13.5D						
APP	D -		BOLTED CONNECTIONS TYPE						
SCA	LE AS SH	HOWN							
ISSU	ED MAR	16	A3	DRAWING	S01-01-01-36				
ALL DIM. IN mm			A 3	NUMBER	301-01-01-30		2		
DRAFTING STANDARD TO A.S.1100				(AD PR	DOUCT - DO NOT AMEND MANUALLY		AMDT		