



ITEM	UNITS	1
ITEM NUMBER	-	407050
RATED OPERATIONAL CURRENT	A	160
MIN. RATED OPERATIONAL VOLTAGE (Ue)	V	400
MIN. RATED INSULATION VOLTAGE (Ui)	V	750
RATED FREQUENCY	Hz	50
UTILIZATION CATEGORY	-	AC-22B
MIN. RATED MAKING CAPACITY	A	480
MIN. RATED BREAKING CAPACITY	A	480
MIN. DEGREE OF PROTECTION	-	IP2X
BUSBAR DISTANCE	mm	185
ACTUATION	-	DEPENDENT MANUAL
MOUNTING POSITION	-	VERTICAL
FUSE SIZE (DIN 43-620)	-	000/00
FUSE CONTACT MATERIAL	-	SILVER PLATED COPPER
TERMINAL MATERIAL	-	TINNED COPPER
TERMINAL CONNECTION	-	1x M8 PER PHASE
TERMINAL TORQUE RATING	Nm	15

**NOTES:**

- FOR FUSE SIZES REFER TO S02-01-04-10.
- DISCONNECTOR MUST CONFORM TO AS/IEC 60947.3 AND STSP 02-014.
- ALL LIVE COMPONENTS MUST BE PROTECTED FROM INADVERTENT TOUCH ACCESS.
- ALL FUSE CONTACTS MUST BE SUPPLIED APPROPRIATELY GREASED.

3	REFORMATTED TABLES, ADDED TECHNICAL DETAILS. ADDED NOTES 2, 3 & 4.	A.N.	FEB'22	B.V.	B.C.
2	TITLEBLOCK & DRAWING NUMBER FORMATTED	K.T.	FEB'19	C.C.	C.C.
1	ITEM NUMBER UPDATED	C.M.	OCT'10	A.T.	S.C.
0	ISSUED FOR CONSTRUCTION	J.C.	OCT'07	B.C.	-
NO	DESCRIPTION	DRN	DATE	CKD	APPD
AMENDMENTS					



DES	B CHEUNG	POWER STANDARD DRAWING		
DRN	J COPPINS	<b>FUSES AND SWITCHGEAR          FUSE BASE STRIPLE FUSE          160A (DISTRIBUTION SERVICE ONLY)</b>		
CKD	B CHEUNG			
APPD	B CHEUNG			
SCALE	N.T.S.			
ISSUED	OCT 07	<b>A3</b>	DRAWING NUMBER	S02-01-04-18
ALL DIM. IN mm				
DRAFTING STANDARD TO A.S.1100			CAD PRODUCT - DO NOT AMEND MANUALLY	

