













TYPE	APPLICATION	DIAGRAMS	BRACKETS REQUIRED	DRAWING NUMBER
t1	TENSION		-	S04-02-01-28
t2	TENSION		-	S04-02-01-28
t3	TENSION/ TEE-OFF		-	S04-02-01-32
t4	TENSION		-	S04-02-04-05
t5	TENSION		-	S04-02-04-05
d1	INTERNAL LARGE ANGLE		DOUBLE CLAMP MOUNTING ITEM No 218222	S04-01-02-08
d2	EXTERNAL LARGE ANGLE		DOUBLE CLAMP MOUNTING ITEM No 218222	S04-01-02-08

LEGEND

-  LINE POLE
-  DOUBLE CLAMP
MOUNTING BRACKET
-  HOOK BOLT (NOTE 1)

NOTES:

1. REFER INSTRUCTIONS FOR THE CORRECT APPLICATION OF HOOK BOLTS FOR CONTROLLED BREAKAWAY DESIGN OR CLOSED HOOK BOLTS FOR NON-BREAKAWAY DESIGN.
2. FOR ALL POLE TOP ARRANGEMENTS WHERE A STREET LIGHT IS REQUIRED, ADD THE PREFIX "L" TO THE TYPE DESCRIPTION AND CALL UP ADDITIONAL BRACKET OUTREACH MOUNTING ITEM No 203661. (FOR EXAMPLE REFER DRG. No. S04-02-02-02).

						<div></div> <div>NORTHERN TERRITORY</div>	DES	B.T.KENT	POWER STANDARD DRAWING			
							DRN	A.DAVIS	POLE TOP UNITS			
							CKD	R.INNES	LV-ABC			
							APPD	F.ROBSON	TENSION - TEE OFF & DEVIATION APP.			
							SCALE	NTS	BRACKET - MOUNTING DIAGRAM			
							ISSUED	MAY'98	A3	DRAWING NUMBER	S04-02-02-04	
							ALL DIM. IN mm					
								DRAFTING STANDARD TO A.S.1100		CAD PRODUCT - DO NOT AMEND MANUALLY		AMDT

4	UPDATED TABLE	J.R.	JUN'25	B.B.	B.V.
3	TITLEBLOCK & DRAWING NUMBER FORMATTED	K.T.	DEC'19	C.C.	C.C.
2	REDRAWN ON CAD	A.D.	MAY'98	R.I.	F.R.
NO	DESCRIPTION	DRN	DATE	CKD	APPD
AMENDMENTS					