



NOTES:

- 1. REFER TO STD DRG S01-02-03-04 FOR EARTHING ARRANGEMENT, DETAILS AND MATERIALS
- 2. POWER FASTENERS TO BE PLACED AT MAX 1000 CENTRES.

ITEM	QTY	DESCRIPTION	ITEM No	DRG REF
6	AR	POWER FASTENERS (EG RAMSET)	-	-
5	3	BOLT M10 X 40LG C/W NUT FLAT, AND SPR WASHER	-	-
4	2	LUG COPPER COMPRESSION - 19/2.14 70sq.mm	5512	-
3	AR	CONDUCTOR - Cu 19/2.14	9803	S01-01-05-05
2	AR	BUSBAR - Cu 25 X 3mm	9837	S01-01-05-05
1	AR	BUSBAR EARTHING - Cu 25 X 4mm	3020	S01-01-05-06

NO	DESCRIPTION	DRN	DATE	CKD	APPD
3	TITLEBLOCK & DRAWING NUMBER FORMATTED	K.T.	JAN'20	C.C.	C.C.
2	ITEM 4 O/LUG CHANGED TO COMPRESSION	K.I.	FEB'05	C.C.	C.C.
1	CHANGES TO NOTES.	R.G.I.	FEB'97	A.G.B.	F.R.R.
AMENDMENTS					



DES	B.KENT	POWER STANDARD DRAWING		
DRN	PWG	EARTHING, LV - ABC SUBSTATION SINGLE POLE		
CKD	g.mck			
APPD	B.KENT			
SCALE	N.T.S.			
ISSUED	SEPT'89	A3	DRAWING NUMBER	S04-02-03-02
ALL DIM. IN	mm			
DRAFTING STANDARD TO A.S.1100		CAD PRODUCT - DO NOT AMEND MANUALLY		AMDT