



NOTES

1. FOR CENTRE PHASE USE DOUBLE INSULATED BRIDGING CONDUCTOR (XLPE 185 sqmm).
2. ALL BOLTS TO BE COATED WITH PRESERVATIVE GREASE.

TAGNo	QTY.	DESCRIPTION	STOCK CODE	DRG REF	TAGNo	QTY.	DESCRIPTION	STOCK CODE	DRG REF
16	18	M16 SPRING WASHER	114322	S01-01-04-15	8	4	INSULATOR PINS (STEEL CROSSARM)	3236	S01-01-04-01
15	36	M16 FLAT WASHER	113951		7	4	PIN TYPE INSULATORS	3178	S01-01-03-05
14	8	M10 SPRING WASHER	114314	S01-01-04-15	6	10	SHUNT PLATES	12138	S01-01-04-14
13	16	M10 FLAT WASHER	113977	S01-01-04-15	5	10	M16 x 160 BOLTS & NUTS	114553	S01-01-04-15
12	8	M16 X 180 BOLTS & NUTS	114561	S01-01-04-15	4	1	'U' BEND TERMINATION	9159	S01-01-04-05
11	8	ANTI - SPLIT BOLTS M10 X 150	114207	S01-01-04-15	3	4	CROSSARM - TIMBER,TERMINATION	16154	S01-01-02-04
10	8	CROSSARM MOUNTING PLATE	9274	S01-01-04-06	2	5	HV SHACKLE STRAPS	9530	S01-01-04-14
9	4	M24 SPRING WASHER	114330	S01-01-04-15	1	21	DISC INSULATOR	3012	S01-01-03-02
MATERIAL SCHEDULE					MATERIAL SCHEDULE				

NO	DESCRIPTION	DRN	DATE	CKD	APPD
4	SUPERSEDED	A.T.	DEC'12	B.C.	B.C.
3	OBSOLETE WARNING NOTICE ADDED	J.A.L.	JAN'97	S.C.M.	F.R.R
2	TITLE & AMENDMENT BLOCK INFORMATION CORRECTED.	J.A.L.	APR'95	S.C.M.	P.J.D
1	CHANGE TO STOCK CODE - TAG 1	G.R.	JUL'94	pmc	A.J.G



DES	-	POWER STANDARD DRAWING	
DRN	G.R.	POLE TOP UNITS	
CKD	pmc	HV 22 kV	
APPD	C.H.Y.	WOODEN CROSSARM	
SCALE	N.T.S	TYPE W	
ISSUED	APR'94	A3	DRAWING NUMBER S01-02-02-13
ALL DIM.	IN mm		
DRAFTING STANDARD TO A.S.1100		CAD PRODUCT - DO NOT AMEND MANUALLY	

