


**NOTES**

- 1. THE TAPE SHALL BE ORANG WITH BLACK LETTERING AS SHOWN
- 2. THE TAPE SHALL BE 150mm WIDE
- 3 THE TAPE SHALL CONFORM IN ALL RESPECTS TO A.S. 2648 PART 1.
- 4. LENGTH 500m/ROLL

# CAUTION CAUTION CAUTION

# BURIED ELECTRIC CABLE BELOW

ITEM NUMBER 6569

9 8	TITLEBLOCK & DRAWING NUMBER FORMATTED REDRAWN IN CAD	K.T. C.C.	FEB'19 NOV'10	C.C. A.T.	C.C. S.C.	 NORTHERN TERRITORY	DES A.TAYLOR	POWER STANDARD DRAWING		
NO	DESCRIPTION	DRN	DATE	CKD	APPD		DRN C.COPPINS	STGNS CABLE MARKER ORANGE TAPE UNDERGROUND	A3	DRAWING NUMBER S02-01-08-05
AMENDMENTS							CKD A.TAYLOR			
						APPD A.TAYLOR	CAD PRODUCT - DO NOT AMEND MANUALLY			
						SCALE N.T.S	DRAFTING STANDARD TO A.S.1100			