



## NOTES:

- 1. THIS INSTALLATION IS FOR LOCATIONS WITH KNOWN FERRORESONANCE AND LINE CURRENT 50A MAX
- 2. FOR EARTHING DETAILS REFER TO S01-02-03-24.
- 3. FOR POLE STRUCTURE DETAILS REFER TO S01-02-05-25.
- 5. ENSURE CABLE DESTINATION TAGS ARE PLACED ON THE CABLE ABOVE THE CABLE PROTECTION CHANNEL AT EACH CABLE TERMINATION POLE.
- 6. HEAT SHRINK COLORED PHASE ID ON EACH CABLE BELOW THE CABLE TERMINATION POINT.
- FOR GROUND LEVEL CONSTRUCTION DETAILS, REFER TO DWG S01-02-04-12
- 9. REFER TO STANDARDS DRAWINGS S02-04-02-09 AND S02-04-02-10 FOR DESIGN CONSIDERATIONS WITH RESPECT TO FERRORESONANCE.
- 10. ALL CABLE CLEATS SHALL BE PWC APPROVED ITEMS. REFER TO S01-04-53.
- 11. ALL SURGE ARRESTORS SHALL HAVE EARTHING TERMINALS INSTALLED, REFER S01-01-05-03 ITEM 2. (DO NOT INSTALL BIRD CAP)
- 12. UPSTREAM ISOLATION TO BE USED FOR THE FUSESAVER REPLACEMENT

| AMENDMENTS |  |       |        |      |      |  |  |  |
|------------|--|-------|--------|------|------|--|--|--|
| NO         | DESCRIPTION  | DRN   | DATE   | CKD  | APPD |  |  |  |
| 0          | ISSUED FOR CONSTRUCTION  | C.C.  | JUL'20 | B.V. | H.E. |  |  |  |
| 1          | REMOVED NOTE 4 & 7. AMENDED NOTE 8. REMOVED ITEM 6,12 & 13. ADDED ITEM 18. | C.C   | APR'22 | B.V. | B.C. |  |  |  |
| 2          | UPDATED CABLE PROTECTION CHANNEL.  | P.BH. | AUGʻ23 | B.V. | B.C. |  |  |  |
|            |  |       |        |      |      |  |  |  |

S01-01-09-52

S01-01-06-18

S01-01-05-03

S01-01-04-10

S01-01-04-17

S01-01-04-53

S02-01-01-34

S02-01-02-11

S01-02-01-01

S02-01-02-21

S01-01-06-06

S01-02-02-34

S01-02-02-33

S01-02-05-25

402089

238915

2121

406718

402692

3863

ITEM NUMBER

18 1 ANIMAL GUARD

14 3 LIVE LINE CLAMP

4 3 EDO ASSEMBLY

1 1 POLE STRUCTURE

TEMQTY DESCRIPTION

17 3 FUSESAVER LINE MOUNT

11 6 CABLE CLEAT TO SUIT HV CABLE

3 BI-METAL TERMINATION

1 POLE TOP UNIT - LV

9 LUG-BELL MOUTH TO SUIT ITEM 10

AR CABLE - CU SINGLE CORE LV FLEXIBLE 70SQMM

7 1 OUTDOOR TERMINATION TO SUIT 11 OR 22KV CABLE

MATERIAL SCHEDULE

SURGE DIVERTER - HB METAL OXIDE

16 3 EARTHING TERMINAL



| DES                           | A.TAYLOR       | POWER STANDARD DRAWING                 |  |               |   |  |  |  |
|-------------------------------|----------------|--|--|---------------|---|--|--|--|
| DRN                           | C.COPPINS      |  | TERMINATIO   |               |   |  |  |  |
| CKD                           | B.CHEUNG       |  |  | O UNDERGROUND |   |  |  |  |
| APPD                          | S.C.           |  | 11kV AND 22kV<br>BOLTED POLES - LINE MOUNTED FUSESAVER |               |   |  |  |  |
| SCALE                         | N.T.S.         | BOLTED I GEES EINE TIGORTED I GSESAVER |  |               |   |  |  |  |
| ISSUED                        | SEPTEMBER 2011 | ۸٦                                     | DRAWING  | S01-02-04-26  |   |  |  |  |
| ALL DIM. IN mm                |                | A3                                     | NUMBER   | 301-02-04-20  | 2 |  |  |  |
| DRAFTING STANDARD TO A.S.1100 |                |  | CAD PRODUCT - DO NOT AMEND MANUALLY                    |               |   |  |  |  |