



ITEM	STOCK CODE	CABLE SIZE	VOLTAGE	TYPE	RAYCHEM PART No	TAIL LENGTH	SIGMAFORM PART No	TAIL LENGTH
1	15883	240 sq.mm COPPER	22 kV	OUT DOOR	EPKT-24D3 MOH4	1200	SATO-22-185/240-B3-1200	1200
2	3590	300 sq.mm	11 kV	INDOOR	EPKT-17D3MIH2	650	SATI-11-300-B3-650	650
3	7609	400 sq.mm ALUMINIUM	11 kV	OUT DOOR	EPKT-17D3MOH4	1200	SATO-11-400-B3-1200	1200
4	7583	400 sq.mm ALUMINIUM	11 kV	INDOOR	EPKT-17D3MIH2	650	SATI-11-400-B3-650	650
5	3574	120 sq.mm COPPER	22 kV	OUT DOOR	EPKT-24C3MOH4	1200	SATO-22-120-B3-1200	1200
6	3566	120 sq.mm COPPER	22 kV	INDOOR	EPKT-24C3MIH2	650	SATI-22-120-B3-650	650
7	3558	25 sq.mm COPPER	22 kV	OUT DOOR	EPKT-24B3MOH4	1200	SATO-22-25/70-B3-1200	1200
8	3541	25 sq.mm COPPER	22 kV	INDOOR	EPKT-24B3MIH2	650	SATI-22-25/70-B3-600	600

NOTES :

- ALL TERMINATION KITS TO CONTAIN INSTALLATION INSTRUCTIONS.
- MATERIALS TO BE HEAT-SHRINKABLE, NON-TRACKING, EROSION RESISTANT, ELECTRICALLY INSULATED, POLYMERIC.
- REFER TO PA.W.A. TECHNICAL SPECIFICATION STS 038 FOR GENERAL REQUIREMENTS AND CONDITIONS OF SERVICE.

7	3	3	H.V. LUG SEALING SLEEVES COATED INTERNALLY WITH 'A' ADHESIVE
6	6	6	H.V. TUBING 50 mm LENGTHS 3 WAY SHED PACKING 25 sq.mm ONLY
5	1	1	MOULDED GLOVE
4	1	1	H.V. 3 WAY SHED
3	6	9	H.V. SINGLE SHED
2	3	3	STRESS GRADE TUBING
1	3	3	OUTER TUBING

TAG No	11 kV 22 kV		DESCRIPTION
	QTY.		
MATERIAL SCHEDULE			

12	SUPERSEDED	A.T.	DEC'12	B.C.	B.C.
11	REDRAWN ON MICROSTATION. SIGMAFORM PART No ADDED.	J.A.L	DEC'95	A.T.	P.J.D
10	NOTE 1 AMENDED, NOTE 3 ADDED.	O.L.F	MAY'88	-	-
NO	DESCRIPTION	DRN	DATE	CKD	APPD
AMENDMENTS					

PowerWater
NORTHERN TERRITORY

DES	R.HAIGH	POWER STANDARD DRAWING CABLE JOINTING & TERMINATIONS TERMINATION KITS 11 kV/22 kV SCREENED PILC CABLES HEAT-SHRINKABLE	
DRN	R.BUZZO		
CKD	K.CHHIT		
APPD	B.KENT		
SCALE	N.T.S.		
ISSUED	NOV'85	A3	DRAWING NUMBER S02-1-2-12
ALL DIM.	IN mm		
DRAFTING STANDARD TO A.S.1100		CAD PRODUCT - DO NOT AMEND MANUALLY	

