



ITEM	STOCK CODE	CABLE SIZE	TYPE	RAYCHEM PART No	TAIL LENGTH	SIGMAFORM PART No	TAIL LENGTH
1	3707	50 sq.mm	INDOOR	EPKT-17B3MIH2	650	SATI-11-50-A3-650	650
2	3715	50 sq.mm	OUTDOOR	EPKT-17B3MOH4	1200	SATO-11-50-A3-1200	1200
3	3723	185 sq.mm	INDOOR	EPKT-17C3MIH2	650	SATI-11-185-A3-600	600
4	3749	185 sq.mm	OUTDOOR	EPKT-17C3MOH4	1200	SATO-11-185-A3-1200	1200

TYPICAL COMPONENTS FOR OUTDOOR KIT

TAG No	QTY	DESCRIPTION
9	3	LUG SEALING SLEEVE (COATED INTERIOR)
8	6	H.V. TUBING (50 mm) 3 WAY SHED PACKING
7	1	THREE WAY SHED
6	6	WEATHER SHED
5	1	BAND RNF 100 T2 (CLEAR)
4	3	SC TUBING (BLACK)
3	3	H.V. TUBING
2	3	RNF 100 T2 (CLEAR) TUBING
1	1	MOULDED GLOVE

NOTES :

- ALL TERMINATION KITS TO CONTAIN INSTALLATION INSTRUCTIONS, ROLLS OF ADHESIVE TAPE, CONTAINER OF H.V. GREASE AND CLEANING SOLVENT
- MATERIALS TO BE HEATSHRINKABLE, NON-TRACKING, EROSION RESISTANT, ELECTRICALLY INSULATED, POLYMERIC.

MATERIAL SCHEDULE

11 SUPERSEDED 10 REDRAWN ON MICROSTATION. SIGMAFORM PART No ADDED. 9 TITLE AND DRAWING No CHANGED						A.T. DEC'12 J.A.L. DEC'95 Q.L.F. MAY'88		B.C. - A.T. - P.J.D. -		POWER STANDARD DRAWING CABLE JOINTING & TERMINATIONS TERMINATION-HEATSHRINK KIT 11 kV-BELTED					
NO	DESCRIPTION					DRN	DATE	CKD	APPD	ISSUED	NOV'85	A3	DRAWING NUMBER	S2-1-2-13	
AMENDMENTS									ALL DIM. IN mm		DRAFTING STANDARD TO A.S.1100				



DES	R.HAIGH
DRN	T.RICARDO
CKD	K.CHHIT
APPD	B.KENT
SCALE	N.T.S.
ISSUED	NOV'85
ALL DIM. IN mm	
DRAFTING STANDARD TO A.S.1100	

DRAWING NUMBER		S2-1-2-13	
CAD PRODUCT - DO NOT AMEND MANUALLY		AMDT	