



NOTES :

1. ALL WELDS SHALL BE 6mm CONTINUOUS FILLET.
2. ALL WORKMANSHIP AND MATERIALS SHALL BE IN ACCORDANCE WITH THE RELEVANT SAA CODES.

4	AS REQ.	BRACKET - SQUARE EDGE FLAT
3	2	1" PLUGS
2	2	1" GATE VALVE OR BALL VALVE
1	AS REQ.	1" STEEL PIPE
ITEM	QTY.	DESCRIPTION

3	REDRAWN ON CAD AND BALL VALVE ADDED	A.S.	NOV '04	R.C.	C.F.		
NO	DESCRIPTION	DRN	DATE	CKD	APPD		
AMENDMENTS							



DES	G. Mc SHANAG	POWER STANDARD DRAWING		
DRN	A. SCHMID	SUBSTATIONS PACKAGE TRANSFORMER OIL PIPES		
CKD	R. CLEOPAS			
APPD	C. FOO			
SCALE	N.T.S.			
ISSUED	NOV '04	A3	DRAWING NUMBER	S02-1-7-2
ALL DIM.	IN mm			
DRAFTING STANDARD TO A.S.1100		CAD PRODUCT - DO NOT AMEND MANUALLY		 AMD T