



FUSES FOR 100 AMP BASE

ITEM No.	STOCK CODE	AMPERE RATING	DIMENSIONS	
			LENGTH	DIAMETER
4	500828	20A	57	22
5	500725	30A	57	22
6	501464	45A	57	22
7	10322	63A	57	22
8	10314	80A	57	22
9	216028	100A	57	22

NOTE :
 FUSE BASE TO SUIT 22 x 58 FUSE.
 LINKS TO BS 1361, UP TO 100A.

ITEM	DESCRIPTION	MAKE	MATERIAL	STOCK CODE
3	SPARE FUSE HOLDER	MICHAUD	-	241117
2	BRACKET	-	ALUMINIUM	406802
1	SERVICE FUSE BASE WITH FUSE HOLDER	MICHAUD	CATALOG No. K291	241109

NO	DESCRIPTION	DRN	DATE	CKD	APPD
3	ADDED FUSE TABLE	P.H.	04/18	I.B.	B.C.
2	ITEM 2 AMENDED. ITEM 3 ADDED.	A.S.	04/07	R.S.	S.C.
1	DIMENSIONS & DETAIL UPDATED ON ITEM 2	K.I.	09/06	RAJ	-
0	ISSUED FOR CONSTRUCTION	A.S.	06/06	RAJ	S.C.



DES	C. CAMILLERI	POWER STANDARD DRAWING		
DRN	J. COPPINS	LINE HARDWARE SERVICE FUSE 100A SERVICE BASE		
CKD	C. CAMILLERI			
APPD	.	A3	DRAWING NUMBER	S01-1-4-49
SCALE	AS SHOWN			
ISSUED	JUNE '06	DRAFTING STANDARD TO A.S.1100		
ALL DIM.	IN mm			
CAD PRODUCT - DO NOT AMEND MANUALLY		AMDT		