



NOTES

1. ABC TO BE TERMINATED DIRECT INTO SWITCH FUSE BOX USING GREASE TO PROHIBIT MOISTURE INGRESS BETWEEN CABLE CORE AND SHEATH.
2. FIT LV SURGE DIVERTERS AT EXPOSED OPEN POINTS.
3. M.E.N. COPPER STRAP TO BE REDIRECTED TO FLANGE SIDE OF POLE FOR MOUNTING OF LV SURGE DIVERTERS.
4. FIX SURGE DIVERTER BRACKET AND M.E.N. STRAP TO POLE WITH POWER FASTENER.
5. SURGE DIVERTER ACTIVE TAILS TO TERMINATE IN SWITCH UNIT IN SPARE TERMINAL HOLE AND ON TOP OF 95 sq.mm CABLE IN SINGLE TERMINAL HOLE.
6. REFER SERVICING DRAWINGS FOR SERVICE ARRANGEMENTS.
7. FIT 160A LINK BLADE (STOCK CODE 205088) IN SWITCH/FUSE BOX.
8. 14mm DIA. HOLE FOR COMPRESSION LUG TO BE DRILLED ON SITE.

15	2	SERVICE CLAMP - STRAIN	-	S1-1-4-28
14	2	HOOK - STRAP	9324	S1-1-4-12
13	2	SERVICE FUSE	-	S1-1-4-12
12	2	PIN - INSULATOR	3251	S1-1-4-1
11	1	BRACE	298687	S1-1-4-38
10	1	LV-SERVICE CROSSARM 100x50x4 DURAGAL CC	298554	S1-1-2-11
9	2	BRACKET - SURGE DIVERTER	214932	S1-1-4-27
8	6	SURGE DIVERTER LV	10041	S1-1-4-20
7	1	SWITCH/FUSE BOX	255943	S4-1-3-1
6	1	LUG COMPRESSION 35 sq.mm	156240	-
5	-	CABLE Cu PVC 35 sq.mm BLACK	1586	-
4	1	CONNECTOR, PIERCING 95/35	415586	S4-1-2-15
3	AR	CABLE LV ABC 4 x 95 sq.mm	197665	S4-1-1-1
2	2	CLAMP STRAIN 4 x 95 sq.mm	197707	S4-1-2-11
1	2	HOOK BOLT M16 NON-BREAKAWAY ASSEMBLY	-	S4-1-2-7
TAG No	QTY	DESCRIPTION	ITEM NUMBER	ORG REF

MATERIAL SCHEDULE

NO	DESCRIPTION	DRN	DATE	CKD	APPD
1	MATERIAL SCHEDULE ITEM NUMBER UPDATED	P.H.	APR'18	I.B.	B.C.
0	ISSUED FOR CONSTRUCTION	A.S.	APR'02	M.B.	F.R.R.
AMENDMENTS					



DES	M. BOCK	POWER STANDARD DRAWING		
DRN	A. SCHMID	ASSEMBLIES LV - ABC - BOLTED CONNECTIONS LINK POLE - OPEN JOINT		
CKD	M. BOCK			
APPD	F. ROBSON	A3	DRAWING NUMBER	S01-2-1-31
SCALE	AS SHOWN			
ISSUED	AUG'01	DRAFTING STANDARD TO A.S.1100		
ALL DIM.	IN mm			
CAD PRODUCT - DO NOT AMEND MANUALLY		AMDT		