



**NOTES**

1. REFER SERVICING DRAWINGS S1-2-1-12 FOR SERVICE ARRANGEMENTS.
2. CABLE TIES TO BE USED AS REQUIRED.
3. 14mm HOLE FOR COMPRESSION LUG TO BE DRILLED ON SITE.
4. NEUTRAL TO BE BONDED TO EVERY POLE.

TAG No.	QTY.	DESCRIPTION	ITEM NUMBER	ORG. REF.
11	1	BRACE	298687	S1-1-4-38
10	1	LV-SERVICE CROSSARM 100x50x4 DURAGAL CC	298554	S1-1-2-11
9	-	CABLE TIE BLACK 8mm	-	-
8	4	CONNECTOR PIERCING 95/95	197715	-
7	1	CLAMP STRAIN 4 x 95 sq.mm	197707	-
6	1	LUG COMPRESSION 35 sq.mm	156240	-
5	-	CABLE Cu PVC 35 sq.mm BLACK	1586	-
4	1	CONNECTOR, PIERCING 95/35	415586	S4-1-2-15
3	-	CABLE LV ABC, 4 x 95 sq.mm	197665	S4-1-1-1
2b	1	CLAMP SUSPENSION COMBINATION 4 x 95 sq.mm	198408	S4-1-2-10
2a	1	CLAMP SUSPENSION 4 x 95 sq.mm	197681	S4-1-2-10
1b	2	HOOK BOLT M16	197731	S4-1-2-7
1a	2	HOOK BOLT M16 NON-BREAKAWAY ASSEMBLY	-	S4-1-2-7

**MATERIAL SCHEDULE**

NO	DESCRIPTION	DRN	DATE	CKD	APPD
1	MATERIAL SCHEDULE ITEM NUMBER UPDATED	P.H.	APR'18	I.B.	B.C.
0	ISSUED FOR CONSTRUCTION	A.S.	APR'02	M.B.	F.R.R.
AMENDMENTS					



DES	M. BOCK	POWER STANDARD DRAWING		
DRN	A. SCHMID	ASSEMBLIES		
CKD	M. BOCK	LV - ABC - BOLTED CONNECTIONS		
APPD	F. ROBSON	SUSPENSION		
SCALE	AS SHOWN	TEE OFF		
ISSUED	AUG'01	A3	DRAWING NUMBER	S01-2-1-32
ALL DIM.	IN mm			
DRAFTING STANDARD TO A.S.1100		CAD PRODUCT - DO NOT AMEND MANUALLY		AMDT