



NOTES

- 1. CONDUCTOR TO BE COPPER
- 2. INSULATION PVC V75 GRADE
- 3. CABLES TO COMPLY WITH AS3147
- 4. INSULATION FOR ITEMS 5-10 AND 15-20 TO COMPLY WITH ESAA S(b)14-1980
- 5. 'ST' INDICATES SPIRAL TRACE

REFER DRAWING S2-1-1-23 FOR OTHER SIZE PVC INSULATED CABLES

ITEM	STOCK CODE	CONDUCTOR STRANDING	INSULATOR COLOUR	CROSS SECT. AREA mm ²	INSULATION THICKNESS mm	OVERALL DIA mm
1	19943	7/0.67	RED	2.5	0.8	3.6
2	213041	7/0.67	WHITE	2.5	0.8	3.6
3	19901	7/0.67	BLUE	2.5	0.8	3.6
4	191361	7/0.67	GREEN/YELLOW	2.5	0.8	3.6
ST 5	246454	7/0.67	RED/BLACK	2.5	0.8	3.6
ST 6	246462	7/0.67	RED/GREY	2.5	0.8	3.6
ST 7	246470	7/0.67	WHITE/BLACK	2.5	0.8	3.6
ST 8	246488	7/0.67	WHITE/GREY	2.5	0.8	3.6
ST 9	246496	7/0.67	BLUE/BLACK	2.5	0.8	3.6
ST 10	246504	7/0.67	BLUE/GREY	2.5	0.8	3.6
11	20016	7/0.85	RED	4.0	1.0	4.9
12	196386	7/0.85	WHITE	4.0	1.0	4.9
13	246512	7/0.85	BLUE	4.0	1.0	4.9
14	246520	7/0.85	GREEN/YELLOW	4.0	1.0	4.9
ST 15	246538	7/0.85	RED/BLACK	4.0	1.0	4.9
ST 16	246546	7/0.85	RED/GREY	4.0	1.0	4.9
ST 17	246553	7/0.85	WHITE/BLACK	4.0	1.0	4.9
ST 18	246561	7/0.85	WHITE/GREY	4.0	1.0	4.9
ST 19	246579	7/0.85	BLUE/BLACK	4.0	1.0	4.9
ST 20	246587	7/0.85	BLUE/GREY	4.0	1.0	4.9
21	19919	7/0.67	YELLOW	2.5	0.8	3.6

1	TABLE ALTERED.	J.A.L.	P.J.D.	JUL '95		DES	A.B	N.T. STANDARD DRAWING				
						DRN	g.l.	CABLES				
No.	AMENDMENT	DRN	CKD	APPD	DATE	NORTHERN TERRITORY	CKD	A.B/ gmck	COPPER-SINGLE CORE			
							APPD	B.T.K.	0.6/1kV			
							SCALE	NTS	PVC - SHEET 2			
							ISSUED	Sept '91	A3	DRAWING NUMBER	S2-1-1-24	
							ALL DIM. IN mm	CAD PRODUCT — DO NOT AMEND MANUALLY				