

 3RD ANGLE — DO NOT SCALE — REPORT ANY ERRORS, OMISSIONS TO DRAFTING OFFICE



NOTES

1. THE TAPE SHALL BE ORANGE WITH BLACK LETTERING AS SHOWN
2. THE TAPE SHALL BE 150mm WIDE
3. THE TAPE SHALL CONFORM IN ALL RESPECTS TO A.S. 2648 PART 1.
4. LENGTH 500m/ROLL

CAUTION CAUTION CAUTION


BURIED ELECTRIC CABLE BELOW

STOCK CODE 6569

			POWER AND WATER AUTHORITY			DES R HAIGH		N T STANDARD DRAWING			
						DRN G WALL		TITLE SIGNS CABLE MARKER ORANGE TAPE UNDERGROUND			
						CKD <i>R.J. Haight</i>					
						APPD <i>Kyler</i> 7/11/83					
						ISSUED 8/11/83					
						DRAFTING STANDARD TO A.S. 1100		A3		DRAWING NUMBER S2-1-8-5	
AMENDMENTS			AMMENDMENTS			ALL DIM IN mm		SCALE NTS		SHEET	AMD.T.

No.	DESCRIPTION	DATE	INIT.
7	TITLE & Drg NUMBER CHANGED	5/88	
6	STOCK CODE ADDED	01.87	<i>R.J.A</i>
5	INDEX N° ALTERED.	0.85	<i>L.P</i>
4	GENERAL REVISION	1.85	<i>T.R.</i>

No.	DESCRIPTION	DATE	INIT.

DES R HAIGH		N T STANDARD DRAWING	
DRN G WALL		TITLE SIGNS CABLE MARKER ORANGE TAPE UNDERGROUND	
CKD <i>R.J. Haight</i>			
APPD <i>Kyler</i> 7/11/83			
ISSUED 8/11/83			
DRAFTING STANDARD TO A.S. 1100		A3	DRAWING NUMBER S2-1-8-5
ALL DIM IN mm		SCALE NTS	SHEET
			
			AMD.T.