

NOTES:

LETTERING

TO BE SIMILAR TO SERIES 'A'
AS 1744 IN NARROW BLOCK TYPE.

COLOUR

BACKGROUND - WHITE
LETTERING & BORDER - 'SIGNAL RED'
CODE R13 IN ACCORDANCE WITH
A.S. 2700.

MATERIAL

BASE - 2mm ANODIZED ALUMINIUM.
PAINT - 1 COAT PRIMER, FOLLOWED BY
2 COATS VITREOUS ENAMEL FOR EACH
COLOUR.

SIGN TO HAVE A LIFE
EXPECTANCY OF 20 YEARS

STOCK CODE 6577



NO	DESCRIPTION	DRN	DATE	CKD	APPD
7	REDRAWN ON CAD. "POWER and WATER" INSTEAD OF PAWA	A.S.	11/02	R.C.	M.B.
6	GENERAL REVISION, TITLE AND DWG. No. CHANGED, NOTES ALTERED	Q.L.J.	05/88		
AMENDMENTS					



DES	R. HAIGH	POWER STANDARD DRAWING			
DRN	S. SANDERS	SIGNS EMERGENCY EXIT SUBSTATION			
CKD	R. HAIGH				
APPD	B.KENT				
SCALE	N.T.S.				
ISSUED	18.7.84	A3	DRAWING NUMBER	S2-1-8-10	7
ALL DIM.	IN mm				
DRAFTING STANDARD TO A.S.1100		CAD PRODUCT — DO NOT AMEND MANUALLY		AMDT	