


NOTES

1. LETTERS AND ASSOCIATED WORDS TO BE IMPRESSED AT 5.0mm DEPTH.
2. ARROWS WILL BE STAMPED ON CONCRETE ACCORDING TO THE DIRECTION OF CABLE ROUTE.

MATERIAL HIGH GRADE STAINLESS STEEL



REFER TO NOTE 1

NO	DESCRIPTION	DRN	DATE	CKD	APPD
1	MATERIAL NOTE ADDED	J.C.	NOV'08	B.C.	S.C.
0	ISSUED FOR CONSTRUCTION	K.I.	JUN'05	R.C.	C.C.
AMENDMENTS					



DES	-	POWER STANDARD DRAWING		
DRN	K.I.	SIGNS UNDERGROUND DANGER BRAND FOR CONCRETE PAVEMENT		
CKD	R.C.			
APPD	C.C.			
SCALE	1:1			
ISSUED	MAY '05	A3	DRAWING NUMBER	S02-1-8-27
ALL DIM. IN mm				
DRAFTING STANDARD TO A.S.1100		CAD PRODUCT — DO NOT AMEND MANUALLY		AMDT