



NOTES:

1. FOR REPLACEMENT OF CFS AND MCCBS IN EXISTING BROWNFIELD SITES.
2. CABLE SHOULD BE MOUNTED WITH A MULTI-CORE TREFOIL CABLE CLEAT WHERE POSSIBLE. REFER TO S02-1-9-03 OR S01-1-4-53

NO	DESCRIPTION	DRN	DATE	CKD	APPD
5	ADDED THICKNESS FOR BAKELITE BOARD	C.C.	MAY'18	I.B.	B.C.
4	NOTES AND REFERENCE DRAWINGS ADDED	A.T.	AUG'16	I.B.	B.C.
3	REDRAWN TO SHOW MOUNTING, METERING AND INTERNAL POWER DETAILS	C.C.	JUN'14	A.T.	B.C.
2	NOTE ADDED, DETAIL SEC B-B BAKELITE CHANGED TO BRAMITE	K.I.	APR '05	R.C.	C.C.
1	TITLE & DRG No. CHANGED	..	JUN'88
AMENDMENTS					



DES	..	POWER STANDARD DRAWING		
DRN	R.P.P.	INDOOR SUBSTATION M.C.C.B. ASSEMBLY DETAILS FOR EXISTING SITES		
CKD	G.McSHANAG			
APPD	..			
SCALE	NTS			
ISSUED	5.2.86	A3	DRAWING NUMBER	S02-2-7-08
ALL DIM. IN	mm			
DRAFTING STANDARD TO AS 1100		CAD PRODUCT — DO NOT AMEND MANUALLY		