



NOTES:

- BUSHINGS TO BE USED BETWEEN BUSBARS & FRAMING.
- ALL CABLES TO BE COLOUR CODED WITH HEAT SHRINK AT BOTH ENDS.
- ALL CABLES ENTERING/LEAVING TO HAVE DESTINATION TAGS, AS PER DRAWING S02-1-8-25.
- READ IN CONJUNCTION WITH S2-1-7-1, STS001.
- "Z" COVER PLATES FITTED BOTH SIDE OF BUS BAR MOUNTS.

LV DISTRIBUTION CUBICLE FRONT

(NOT SHOWING STRIPLE FUSE UNITS FOR CLARITY SEE S2-1-7-1 FOR STRIPLE FUSES)

6	AS REQ	INSULATING BOBBINS	S02-1-7-09	-
5	1	REMOVABLE LINK OR 90Sqmm Cu LUGGED CABLE	S02-1-7-09	-
4	1	EARTH BUSBAR - 50x6.3 TINNED Cu	S02-1-7-09	-
3	1	NEUTRAL BUSBAR - 50x6.3 TINNED Cu	S02-1-7-09	-
1	3	PHASE BUSBARS	S02-1-7-09	-
ITEM	QTY	DESCRIPTION	DWG No.	STOCK CODE

NO	DESCRIPTION	DRN	DATE	CKD	APPD
AMENDMENTS					



DES B.C.	POWER STANDARD DRAWING	
DRN K.L.	PACKAGE SUBSTATIONS	
CKD B.C.	LOW VOLTAGE COMPARTMENT	
APPD S.C.	GENERAL ARRANGEMENT	
SCALE N.T.S.	A3	DRAWING NUMBER S02-2-8-01
ISSUED JUL'06		
ALL DIM. IN mm	CAD PRODUCT - DO NOT AMEND MANUALLY	
DRAFTING STANDARD TO A.S.100	AMD T	