APPLICATION NOTES - POWER DIRECTORATE

1. PURPOSE

THESE DRAWINGS WERE COMPILED TO RECORD ALL KNOWN AGREED SERVICE ALLOCATION ALIGNMENTS WITHIN THE NORTHERN TERRITORY FOR THE PURPOSE OF THE CORPORATION FOR THE PLACEMENT OF POWER AND WATER SERVICES ASSETS WITHIN GAZETTED ROAD RESERVES.

INDICATION OF SERVICES OTHER THAN POWER AND WATER ASSETS ARE INDICATIVE ONLY AND THIS INFORMATION IS NOT TO BE USED FOR ANY PURPOSE WITHOUT PRIOR CONSULTATION WITH THE RELEVANT AUTHORITY. (SEE 5.2)

2. ADDITIONS/ALTERATIONS TO SERVICES IN ESTABLISHED AREAS.

DATES INDICATED ON DRAWING TITLES REFLECT THE PERIOD AT WHICH ALIGNMENT AGREEMENTS WERE/ARE CURRENT FOR THE GENERAL AREAS LISTED, HOWEVER AN EXHAUSTIVE LIST OF LOCATIONS/SUBURBS APPLICABLE TO THESE AGREEMENTS IS NOT AVAILABLE.

USERS OF THIS DATA SHOULD ESTABLISH THE APPLICABLE SERVICES ALLOCATION DRAWING, WHERE NOT APPARENT, BY MEASURE OF EXISTING SERVICES/ASSETS (e.g. DISTANCE FROM POWER POLE TO ROAD BOUNDARY etc.)

EXTENSIONS AND ALTERATIONS CONTIGUOUS WITH EXISTING SERVICES SHALL BE PLACED IN ACCORDANCE WITH THE SERVICE ALLOCATION DRAWING APPLICABLE TO THOSE EXISTING SERVICES.

3. NEW INSTALLATIONS

SERVICE ALIGNMENTS IN NEW DEVELOPMENTS SHALL BE PLACED IN ACCORDANCE WITH THE CURRENT SERVICE ALLOCATION DRAWINGS APPLICABLE TO THE ROAD TYPE AND AREA.

NO VARIATION TO THE ABOVE WILL BE MADE WITHOUT PRIOR CONSULATION AND WRITTEN AGREEMENT BY THE MANAGER NETWORK ENGINEERING. NOTE THAT PROPOSED VARIATIONS TO SERVICE ALLOCATIONS WILL NORMALLY ONLY BE CONSIDERED IN EXCEPTIONAL CIRCUMSTANCES.

4. STREET LIGHTING

PLACEMENT OF STREET LIGHT COLUMNS IN RURAL AREAS OR ON ARTERIAL ROADS IS TO BE IN ACCORDANCE WITH DRAWINGS S2-4-1-14. IN ADDITION OR ALTERNATIVELY COLUMNS MAY BE PLACED ON MEDIAN STRIPS PROVIDED STANDARD SAFETY ENGINEERING PRACTICES ARE ADHERED TO IN MAINTAINING SAFE SET BACK DISTANCES.

5. GENERAL

5.1 THE SPACE ALLOCATED FOR SERVICES, FOR CLARITY IS NORMALLY SHOWN ONLY ON ONE SIDE OF THE ROAD CROSS SECTION. AN EQUAL ALLOCATION OF SPACE, UNLESS EXPRESSELY NOTED OTHERWISE ON THE DRAWINGS, IS AVAILABLE ON THE OPPOSITE SIDE OF THE ROAD.

5.2 IN ORDER TO CO-ORDINATE WORKS, DESIGNS FOR ADDITIONS/ALTERATIONS OR NEW INSTALLMENTS SHALL BE CIRCULATED TO THE AUTHORITIES LISTED BELOW FOR COMMENT AT LEAST 4 WEEKS PRIOR TO PROPOSED COMMENCEMENT OF WORKS.

-DEPARTMENT OF INFRASTRUCTURE, PLANNING AND ENVIRONMENT
-POWER AND WATER CORPORATION
-TELSTRA.
-LOCAL COUNCIL RESPONSIBLE FOR AREA OF WORKS (i.e. DARWIN CITY COUNCIL)
-AUSTRALASIA RAILWAYS CORPORATION (WHERE RAILWAY ASSETS ARE INVOLVED)
-NT GAS (WHERE GAS PIPELINE CROSSINGS ARE INVOLVED)
-DEPARTMENT OF CIVIL AVIATION (FOR WORKS CLOSE TO AIRPORT BOUNDARIES)
-DEFENCE FORCES - ARMY, NAVY OR AIR FORCE (WHERE WORKS ARE NEAR DEFENCE & COMMUNICATION INSTALLAIONS)
-CABLE TV

NO	DESCRIPTION	DRN	DATE	CKD	APPD
1	UPDATE LOGO, AUTHORITY NAMES, POSITION NAMES	K.I.	MAR '05	R.C.	C.C.
0	ISSUED FOR CONSTRUCTION	T.G.	MAR '90	T.G.	B.K.

AMENDMENTS

PowerWater

DES	T.G
DRN	H.T
CKD	T.G
APPD	B.K
SCALE	
ISSUED	MAR '90
ALL DIM. IN mm	

POWER STANDARD DRAWING

SERVICE ALLOCATION IN ROAD RESERVES
APPLICATION NOTES
POWER DIRECTORATE

A3 | DRAWING NUMBER S2-4-1-01 | 1 AMDT

DRAFTING STANDARD TO AS 1100 | CAD PRODUCT — DO NOT AMEND MANUALLY

A3 297 X 420