



DETAIL A 1:5, 2 OFF



DETAIL B 1:5



DETAIL C N.T.S.

STOCK CODE	No OF LV ARMS	No OF HV ARMS	LENGTH	
			A	B
NSI	2	2	1118	3505
402983	1	1	1727	4115
	1	2	1727	4115
	2	1	1727	4115
	2	3	1727	4115
NSI	1	3	2489	4877

APPLICATION GUIDE

NOTE: DIMENSION B IS THE TOTAL LENGTH OF 40mm NB PIPE REQUIRED TO FABRICATE EACH BRACKET.

NO	DESCRIPTION	DRN	DATE	CKD	APPD
5	FUSE RELOCATED, CONDUIT ADDED	J.C	MAR'09	A.T.	S.C
4	TABLE REDRAWN WITH STOCK CODE	K.I	JUL'05	C.C.	C.C.
3	REDRAWN AS MICROSTATION CAD FILE	RGI	04/01	MWB	FRR
2	TITLE AND DRAWING NUMBER CHANGED	...	11/87	...	...
1	TEXT "NOT A STOCK ITEM" ADDED	...	01/87	...	BK
AMENDMENTS					



DES	G. McSHANAG	POWER STANDARD DRAWING		
DRN	G. McSHANAG	<b>BRACKET LANTERN OUTREACH HIGH RISE</b>		
CKD	...			
APPD	...			
SCALE	...			
ISSUED	20/02/86	A3	DRAWING NUMBER	S3-1-3-3
ALL DIM. IN	mm			
DRAFTING STANDARD TO A.S.1100		CAD PRODUCT — DO NOT AMEND MANUALLY		AMDT