



NOTES

1. ALL WELDS AND BLACK METAL SURFACES TO BE CLEANED AND COATED WITH COLD GALVANISING COMPOUND.
2. ALL WELDING AND WELD PREPARATION TO BE IN ACCORDANCE WITH AS 1554. SYMBOLS COMPLY WITH AS 1101 PART 3.
3. BOTH FLANGES OF BRACKET TO BE WELDED TO POLE WITH STANDARD FULL STRENGTH STRUCTURAL WELDS.
4. BOND NEUTRAL TO POLE VIA RAMSET STUD
5. EARTH CONDUCTOR SIZE TO BE 16 sq mm STRANDED COPPER.
6. POLARITY OF NEUTRAL/EARTH CONNECTION TO BE CONFIRMED DURING COMMISSIONING AND AFTER MAINTENANCE.

6	1	FUSED MAINS CONNECTION BOX	6866	
5	1	OUTREACH TAPERED STEEL		S3-1-1-10
4	2	HOOK STRAP	9324	S1-1-4-7
3	3	BOLT M16 x 50mm LONG	114504	
2	1	MOUNTING BRACKET	8664	S3-1-3-1
1	1	STEEL COLUMN 10.7 METRE	8920	S3-1-1-3

TAG No	QTY.	DESCRIPTION	STOCK CODE	DRG REF
--------	------	-------------	------------	---------

MATERIAL SCHEDULE

DES	N.S	N.T. STANDARD - POWER		
DRN	R.T.F	BRACKET TAPERED OUTREACH ASSEMBLY DETAILS		
CKD	N.S			
APPD	B.K			
SCALE	1:6			
ISSUED	MAY'90	A3	DRAWING NUMBER	S3-1-3-8
ALL DIM. IN mm				

3	NOT FOR NEW CONSTRUCTION	I.B.	A.T.	I.B.	SEP '16
2	NOTES 3,4,5&6 ADDED	J.A.L.	A.G.B.	P.J.D.	3/95
1	NOTES ADDED.	R.T.F	N.S.	N.S	9/90
No.	AMENDMENT	DRAWN	CHK'D	APPD	DATE

