



NOTES :

1. SWITCH PACK SUITABLE FOR ALL POST TOP AND OUTREACH TYPE COLUMNS 4.5 m - 18 m INCLUSIVE.
2. ADDITIONAL CIRCUIT BREAKER(S) (STOCK CODE 8482) TO BE FITTED ON SITE FOR DOUBLE OUTREACH OR 18 m TRIPLE OUTREACH LOCATIONS.
3. ALL MOUNTING HOLES TO BE 4 mm DIA
4. SECURE RAIL AND CIRCUIT BREAKER(S) WITH SELF TAPPING SCREWS (COUNTER SUNK FOR RAIL.)
5. BASE PLATE TO BE DRILLED FOR TWO FUTURE CIRCUIT BREAKERS.
6. MOUNTING BRACKET TO BE RIVETED TO BASEPLATE.

MOUNTING DETAIL

TO BE READ IN CONJUNCTION WITH S3-1-5-7 WIRING DIAGRAM

ITEM 1 - SWITCH PACK LIGHTING COLUMN (INTEGRAL) (S/C 6890)

TAG No	QTY	DESCRIPTION	STOCK CODE	DRG REF
15	1 m	PIPE 25mm PVC RED	19943	-
14	1	MOUNTING BRACKET	-	-
13	1	UTILITY RAIL	6536	-
12	2	UTLTY END ARM	7278	-
11	2	UTILITY BUSH BAR	-	-
10	2	UTILITY BASE BAR	7393	-
9	6	UTLTY TERMINAL BLOCK	7229	-
8	1	UTILITY BASE PLATE	7252	-
7	1	HEINER C/BREAKER CF TYPE 10A(SEE NOTE 2)	8482	-
6	2	STAINLESS STEEL 5 mm NUTS	-	-
5	2	STAINLESS STEEL 5 mm BOLT	-	-
4	1	STAINLESS STEEL 5 mm SPLIT WASHER	-	-
3	1	STAINLESS STEEL 5 mm WASHER	-	-
2	1	STAINLESS STEEL 5 mm 'STANKO' LUG	-	-
1	1	ALUMINIUM BASE PLATE 560mm X 85mm X 3mm	-	-

MATERIAL SCHEDULE

1	REDRAWN ON C.A.D. DIMENSIONS AND PARTS LIST AMENDED. WARNING NOTICE ADDED.	J.A.L.	S.C.M.	P.J.D.	MAY'95	
	AMENDMENT	DRN	CKD	APPD	DATE	

DES	G.S.	N.T. STANDARD DRAWING		
DRN	H.T.	CONTROL DATA SWITCH PACK LIGHTING COLUMNS INTEGRAL - SINGLE PHASE		
CKD	G.S./gmck			
APPD	B.KENT			
SCALE	N.T.S.			
ISSUED	NOV'88	A3	DRAWING NUMBER	S3-1-5-6
ALL DIM. IN	mm		CAD PRODUCT	DO NOT AMEND MANUALLY