


3RD ANGLE — DO NOT SCALE — REPORT ANY ERRORS, OMISSIONS TO DRAFTING OFFICE



NOTE

- CONTROL GEAR ASSEMBLY SHALL INCLUDE THE FOLLOWING —
 CHOKE FERGUSON TYPE MF400TA FOR 400WATT.
 OR TYPE MF250TA FOR 250WATT.
 CAPACITOR

TECHNICAL DATA

FOR OUTDOOR USE UNDER EXTREME TROPICAL CONDITIONS
 AS 1158
SPECIAL CRITERIA FOR N.T. PUBLIC LIGHTING LANTERNS.

1. DELETION OF BUILT IN FUSE WITHIN LANTERN.
2. PROVISION OF REMOVABLE CONTROL GEAR TRAY.
3. PROVISION OF QUICK DISCONNECT PLUG BETWEEN PORCELAIN BLOCK AND REMOVABLE TRAY. (SIMILAR TO UTILUX M/N 1545-2)
4. EARTH ATTACHMENT TO BODY OF LANTERN.
5. LANTERN TO COMPLY WITH AS 3771 FOR CATEGORY 'A' ROAD LUMINAIRES.

ITEM	LANTERN	STOCK CODE	AEI. CAT NO
1	250W	11650	SL 4864 / 25
2	400W	11668	SL 4864 / 40
3	VISOR	6601	TAG No. 2

TAG No.	QTY.	DESCRIPTION	DRG. N°
9	1	GASKET CONT. GEAR ASSY. NEOPRENE	---
8	1	GASKET BOWL NEOPRENE	---
7	1	HOLDERS LAMP PORCELAIN G.E.S.	---
6	1	CHOKE 250W FERGUSON MF250TA.	---
5	1	CHOKE 400W FERGUSON MF400TA.	---
4	1	CAPACITOR 15MFD FOR 250W	---
3	1	CAPACITOR 20MFD FOR 400W	---
2	1	VISOR ACRYLIC CAT N°	---
1	1	REFLECTOR ALUMINIUM CAT N°	---

MATERIALS SCHEDULE

No.	AMENDMENT	DATE	INIT
5	NOTES AMENDED	FEB 91	R.T.F.
4	ITEM 3 - STOCK CODE 6601 ADDED	9/89	R.T.F.
3	NOTE N°6 ADDED	6/89	@
2	TITLE & DRAWING NUMBER CHANGED	12/87	Q.L.F.
1	ITEM & STOCK CODES ADDED	01.87	W.T.

POWER AND WATER AUTHORITY

POWER DIRECTORATE

DES GMS.
 DRN 2PP FOR R.
 CKD G.M.S.
 APPD W.T.
 ISSUED 20.2.86
 DRAFTING STANDARD TO A.S. 1100
 ALL DIM. IN m.m.

STANDARD DRAWING

TITLE LANTERN & LAMPS
 MAJOR ROADS
 MERCURY VAPOUR 250-400W

DRAWING NUMBER S3-1-4-7

A3 SCALE SHEET

AMD/T