



STOCK CODE : 207183

MATERIAL : 40 x 8 FLAT

NOTES :

1. ALL WORKMANSHIP AND MATERIALS SHALL BE IN ACCORDANCE WITH AS1204.
2. ALL ROUGH AND BURRED EDGES ARE TO BE DRESSED CLEAN.
3. BRACKET TO BE HOT DIP GALVANISED, WHEREBY COMPONENTS ARE TO BE EVEN AND FREE OF LUMPS AND BUILD-UP AND TRUE TO SHAPE AFTER GALVANISING. COMPONENTS WILL BE TESTED IN ACCORDANCE WITH AS1650.

NO	DESCRIPTION	DRN	DATE	CKD	APPD
2	STOCK CODE CHANGED	A.S.	MAY'07	R.S.	S.C.
1	STOCK CODE ADDED	A.S.	29.1.04	R.C.	M.B.
0	ISSUED FOR CONSTRUCTION, REPLACES S4-1-2-1	A.S.	18.9.02	M.B.	M.B.
AMENDMENTS					

PowerWater

DES	M. BOCK	POWER STANDARD DRAWING		
DRN	A. SCHMID	LINE HARDWARE LV - ABC TERMINATION/BOLTED CONNECTIONS FUSE SWITCH BRACKET		
CKD	M. BOCK			
APPD	M. BOCK	A3	DRAWING NUMBER	S04-1-2-4
SCALE	1 : 5			
ISSUED	SEPT'02	DRAFTING STANDARD TO A.S.1100		
ALL DIM.	IN mm			
CAD PRODUCT - DO NOT AMEND MANUALLY		AMDT		

A3 297 X 420