



**NOTES :**

1. UP TO 2 SINGLE PHASE SERVICES CAN BE CONNECTED DIRECT TO ABC. FOR ARRANGEMENTS REQUIRING MORE THAN 5 PIERCING CONNECTORS, USE POLE MOUNTED JUNCTION BOX. REFER TO DRG S4-1-2-15 FOR DETAILS.
2. ACTIVE SERVICE TEE-OFF TO BE BALANCED OVER THREE PHASES ON SUBSEQUENT POLES.
3. SERVICES TO BE CONNECTED TO FUSE HOLDER DIRECTLY OPPOSITE SERVICE HOOK.
4. FOR FUSE HOLDER ASSEMBLY DETAILS REFER TO S01-1-4-49

13	X	BOLT & NUT M16 X 50 ZINC PLATED	114504	-
12	X	HOOK STRAP	9324	S1-1-4-7
11		CONDUCTOR SERVICE 2 X 7/1.70	9779	-
9	X	ALUMINIUM BRACKET	4106802	S01-1-4-49
8	X	SERVICE FUSE BASE WITH FUSE HOLDER	241109	S01-1-4-49
7	1	LUG COMPRESSION 35sq.mm	156240	-
6	-	CABLE Cu PVC 35sq.mm BLACK	1586	-
5	-	CONNECTOR, PIERCING 95/35	197723	S4-1-2-15
4	-	CABLE LV ABC, 4 X 95sq.mm	197665	S4-1-1-1
3b	1	CLAMP SUSPENSION COMBINATION 4 X 95sq.mm	198408	S4-1-2-10
3a	1	CLAMP SUSPENSION 4 X 95sq.mm	197681	S4-1-2-10
2b	1	HOOK BOLT M16	197731	S4-1-2-7
2a	1	HOOK BOLT M16 NON-BREAKAWAY ASSEMBLY	-	S4-1-2-7
1	1	BRACKET HOOK MOUNTING	203679	S4-1-2-2
TAG No	QTY	DESCRIPTION	STOCK CODE	DRG REF

**MATERIAL SCHEDULE**

NO	DESCRIPTION	DRN	DATE	CKD	APPD
2	CIRCUIT BREAKERS REPLACED WITH FUSE HOLDERS	J.C.	FEB'08	A.T.	S.C.
1	REDRAWN ON CAD	A.D.	JAN'98	R.I.	F.R.
AMENDMENTS					

**PowerWater**  
NORTHERN TERRITORY

DES	B.T.KENT	POWER WATER STANDARD DRAWING	
DRN	A.DAVIS	<b>ASSEMBLIES</b>	
CKD	R.INNES	<b>LV - ABC</b>	
APPD	F.ROBSON	<b>1 - 2 SERVICES</b>	
SCALE	N.T.S.	<b>INTERMEDIATE SUSPENSION</b>	
ISSUED	MAY'98	<b>A3</b>	<b>DRAWING NUMBER</b> S4-2-1-14
ALL DIM. IN mm			
DRAFTING STANDARD TO A.S.1100		CAD PRODUCT - DO NOT AMEND MANUALLY	

