



NOTES

1. JUNCTION BOX TO BE POWER FIXED TO POLE AT POSITION SHOWN.
2. 35sq.mm ACTIVE TAILS TO BE PHASE COLOURED WITH HEATSHRINK TUBING BEFORE CONNECTION TO JUNCTION BOX.
3. FOR DETAILS OF FUSE HOLDER AND COMPONENTS REFER TO DRAWING No. S01-1-4-49
4. SERVICES TO BE CONNECTED TO FUSE HOLDER DIRECTLY OPPOSITE SERVICE HOOK.

17	-	TUBING HEATSHRINK 19 - 9.5mm - RED	4093	
16	-	TUBING HEATSHRINK 19 - 9.5mm - WHITE	4101	
15	-	TUBING HEATSHRINK 19 - 9.5mm - BLUE	4127	
14	2	JUNCTION BOX POLE TOP 4 WIRE	206169	S4-1-3-4
13	-	TIE CABLE PLASTIC BLACK		
12	8	SERVICE FUSE HOLDER	-	S01-1-4-49
11	2	DEAD END 2 CORE	4119	S1-2-1-8
10	-	CONDUCTOR TWISTED SERVICE 2 CORE 7/1.70	9779	S1-1-7-1
9	4	HOOK STRAP	9324	S1-1-4-7
8	1	CROSSARM SERVICE	9555	
7	1	LUG COMPRESSION 35sq.mm	156240	
6	-	CABLE Cu PVC 35sq.mm BLACK PVC	1586	-
5	5	CONNECTOR, PIERCING 95/35sq.mm	197723	S4-1-2-15
4	-	CABLE LV ABC, 4x95sq.mm	197665	S4-1-1-1
3	1	CLAMP SUSPENSION 4x95sq.mm	197681	S4-1-2-10
2b	-	HOOK BOLT M16	197731	S4-1-2-7
2a	-	HOOK BOLT M16 NON BREAKAWAY ASSEMBLY		S4-1-2-7
1	1	BRACKET HOOK MOUNTING	203679	S4-1-2-2
TAG No	QTY	DESCRIPTION	STOCK CODE	DRG. REF

VIEW **A**
SCALE 1:10

ELEVATION
SCALE 1:10

NO	DESCRIPTION	DRN	DATE	CKD	APPD
3	CURRENT BREAKER REPLACED WITH FUSE HOLDER	J.C.	FEB'08	B.C.	S.C.
2	2nd JUNCTION BOX (ITEM 14) ADDED	A.S.	JUNE'07	B.C.	S.C.
1	REDRAWN ON CAD	A.D.	MAY'98	R.I.	F.R.
AMENDMENTS					

DES	B.T. KENT	POWER STANDARD DRAWING	
DRN	A. DAVIES	ASSEMBLIES LV - ABC 3 - 4 SERVICES INTERMEDIATE SUSPENSION	
CKD	R. INNES		
APPD	F. ROBSON		
SCALE	AS SHOWN	A3	DRAWING NUMBER S04-2-1-15
ISSUED	MAY'98		
ALL DIM.	IN mm	CAD PRODUCT - DO NOT AMEND MANUALLY	
DRAFTING STANDARD TO A.S.1100			