



NOTES :

- 1. 1.5 m OUTREACH SHOWN
- 2. SELECT ITEM 5 BASED ON POLE WIDTH FOR POLES LESS THAN 200mm WIDE USE S.C. 203611.

10	A/R	BOX, POLE MOUNTED CIRCUIT BREAKER	206490	S4-1-3-3
9	3	PIN, LINE INSULATOR, HV	-	S1-1-4-1
8	A/R	HOOK STRAP, SERVICE	9324	S1-1-4-7
7	1	CROSSARM, SERVICE	9555	S1-1-2-1
6	1	LV ABC - INTERMEDIATE SUSPENSION	-	S4-2-1-5
5	1	BRACKET, OUTREACH MOUNTING, ABC	8664/203661	S3-1-3-1/ S04-1-2-2
4	1	LANTERN	-	S3-1-4-1
3	1	S/L OUTREACH	-	S3-1-1-10
2	1	CROSSARM - STEEL	-	S1-1-2-2
1	1	POLE, LINE	-	S1-1-1-2
TAG No	QTY	DESCRIPTION	STOCK CODE	DRG REF

MATERIAL SCHEDULE

2	NOTE 2 ADDED. ITEM 5 ALTERNATIVE ADDED	K.I.	SEP '05	C.C.	C.C.
1	DIMENSION FOR PLACEMENT OF MOUNTING BRACKET AMENDED & MATERIALS LIST ADD	J.A.L.	MAY '95	A.G.B.	P.J.D.
NO	DESCRIPTION	DRN	DATE	CKD	APPD
AMENDMENTS					



DES	B.T.KENT	POWER STANDARD DRAWING		
DRN	g.mck	ASSEMBLIES LV - ABC SERVICES & STREET LIGHT GENERAL CONSTRUCTION		
CKD	G.Schubert			
APPD	B.T.KENT			
SCALE	1:10			
ISSUED	SEPT'89	A3	DRAWING NUMBER	S04-2-1-18
ALL DIM.	IN mm			
DRAFTING STANDARD TO A.S.1100		CAD PRODUCT - DO NOT AMMEND MANUALLY		AMD T

