



NOTES

- 1 NEUTRAL BOND TO BE CONTINUOUS THROUGH PIERCING CONNECTOR INTO NEUTRAL LINK IN JUNCTION BOX.
- 2 35mmsq Cu ACTIVE TAILS TO BE PHASE COLOURED WITH TAPE BEFORE CONNECTION TO JUNCTION BOX.
- 3 SERVICES TO BE TAKEN FROM JUNCTION BOX SEE DRG. S4-2-1-15.
- 4 M.E.N. TO BE FITTED SEE DRG. S4-2-3-1.
- 5 PIERCING CONNECTOR GREASE CAPS TO BE FITTED OVER ABC.
6. SURGE DIVERTER BRACKET TO BE POWER FASTENED TO POLE AND M.E.N. STRAP

11	3	CONNECTOR, PIERCING 95/35	197723	S4-1-2-15
10	-	JUNCTION BOX	206169	S4-1-3-4
9	1	BRACKET - SURGE DIVERTER	214932	S1-1-4-27
8	3	SURGE DIVERTER LV	206664	S1-1-4-20
7	1	LUG COMPRESSION 35mmsq	156240	
6	-	CABLE Cu PVC 35mmsq BLACK	1586	
5	4	CONNECTOR, PIERCING 95/95	197715	S4-1-2-15
4		CABLE LV ABC, 4x95mmsq	197665	S4-1-1-1
3	1	CLAMP STRAIN 4x95mmsq	197707	S4-1-2-11
2b	1	HOOK BOLT M16	197731	S4-1-2-7
2a	1	HOOK BOLT M16 NON-BREAKAWAY ASSEMBLY		S4-1-2-7
1	1	BRACKET HOOK MOUNTING	203679	S4-1-2-2
TAG No	QTY	DESCRIPTION	STOCK CODE	DRG REF

MATERIAL SCHEDULE

DES	B.T.KENT	N.T. STANDARD		
DRN	H.T./g.mck	CABLE TERMINATION LV - ABC TERMINATION & SURGE DIVERTERS		
CKD	G.Schubert			
APPD	B.T.KENT			
SCALE	as shown			
ISSUED	SEPT '89	A3	DRAWING NUMBER	S4-2-4-1
ALL DIM.	IN mm			
DRAFTING STANDARD TO AS 1100		CAD PRODUCT - DO NOT AMEND MANUALLY		AMDT

VIEW
Scale 1: 10

ELEVATION
Scale 1: 10

No.	1	DRAWING REFERENCE FOR TAG No. 9 REVISED. NOTE 6 AMENDED.	gnck	may '91	N.S.	<p>POWER AND WATER AUTHORITY</p> <p>POWER DIRECTORATE</p>
		AMENDMENT	DRAWN	DATE	APPD	